

Living a Marginal Existence

 phius con
CHICAGO 2022

October 28, 2022



Skylar Swinford
Energy Systems Consultants



Zack Semke
Passive House Accelerator



Dan Whitmore
Passive House Consultant

Passive House and Embodied Carbon reduction aren't tradeoffs.
Passive House reduces a building's total emissions, even by 2030,
while *also* decarbonizing winter heating peaks.
Choosing low-embodied carbon materials also reduces emissions.
...so let's do both.



Passive House

+



Carbon-Sequestering
Materials

+



Electrify
Everything

+



Clean
Energy

=



Zero Carbon Building

Winter Peak


“Required reading for an economy-wide green transition in the USA.”

MARIANA MAZZUCATO, AUTHOR OF *MISSION ECONOMY*

ELECTRIFY

AN
OPTIMIST'S PLAYBOOK
FOR OUR
CLEAN ENERGY
FUTURE

SAUL GRIFFITH



8.6 Modeled seasonal variations by energy sector if loads were almost completely electrified.

But What About Embodied Carbon?

Common Assumptions About Embodied Carbon and Achieving Decarbonization

1. The “smaller is better” fallacy suggests that smaller systems have higher EC and often higher overall emissions. **Did you account for the smaller EC and refrigerant leaks from smaller systems in a low load building?**

2. The “net-zero by 2050” dictates that 2030 is the important time horizon, not 2050. **What about the “Time Value of Efficiency?”**

3. If my building is near-zero emissions, then building energy use isn't that important. **Not according to the EPA!**

Operational and Embodied Carbon Emissions Estimator

**Operational
& Embodied Carbon Emissions Estimator**
BETA
October 2022

| Emission Factors | Units | Case 1 | Case 2 | |
|------------------|--------------------------|--------|--------|----|
| Electricity | lb CO ₂ e/MWh | 936 | 936 | 0% |
| Natural Gas | lb CO ₂ e/MWh | 681 | 681 | 0% |

| Building Inputs | Units | Case 1 | Case 2 | |
|--------------------------------|--------------------------|--------|--------|------|
| Floor Area | ft ² | 10,000 | 10,000 | 0% |
| EUI | kBTU/ft ² .yr | 30.0 | 15.0 | -50% |
| Energy Use Per Year | kWh/yr | 87,925 | 43,962 | -50% |
| Space Heating Fraction | % | 50% | 25% | -50% |
| Gas Fraction of Heat | % | 0% | 0% | 0% |
| Electric Fraction of Heat | % | 100% | 100% | 0% |
| Heat Gas Emissions | lb CO ₂ e/yr | 0 | 0 | 0% |
| Heat Electricity Emissions | lb CO ₂ e/yr | 41,149 | 10,287 | -75% |
| Heat Emissions Total | lb CO ₂ e/yr | 41,149 | 10,287 | -75% |
| Non-Heat Electricity Emissions | lb CO ₂ e/yr | 41,149 | 30,862 | -25% |
| Total Operational Emissions | lb CO ₂ e/yr | 82,298 | 41,149 | -50% |

| Heat Pump Inputs | Units | Case 1 | Case 2 | |
|---|--------------------------|---------|---------|------|
| Heat Pump Capacity | Tons | 10.0 | 5.0 | -50% |
| Floor Area/Capacity | ft ² /Ton | 1,000 | 2,000 | 100% |
| Heating Equipment Emission (IU/OU) | lb CO ₂ e/Ton | 1,552 | 1,552 | 0% |
| Total Heat Equipment Emissions (no refrigerant) | lb CO ₂ e | 15,521 | 7,760 | -50% |
| Refrigerant Charge | lb/Ton | 3.50 | 3.50 | 0% |
| Total Refrigerant Charge | lb | 35.00 | 17.50 | -50% |
| Refrigerant Type | Select | R-410A | R-410A | |
| User Specified GWP | GWP | 0 | 0 | 0% |
| Refrigerant GWP | GWP100 | 2,088 | 2,088 | 0% |
| Refrigerant GWP | GWP20 | 4,340 | 4,340 | 0% |
| Total Refrigerant GWP100 | lb CO ₂ e | 73,063 | 36,531 | -50% |
| Total Refrigerant GWP20 | lb CO ₂ e | 151,900 | 75,950 | -50% |
| Refrigerant Leakage Rate | % | 5% | 5% | 0% |
| Average Heat Pump Life | Years | 15 | 15 | 0% |
| End-of-life recovery of remaining refrigerant | % | 20% | 20% | 0% |
| Last year of refrigerant "top-off" before EOL | Years | 12 | 12 | 0% |
| Percentage of refrigerant lost during lifetime | % | 143% | 143% | 0% |
| Mass of refrigerant lost during lifetime | lb | 50.1 | 25.0 | -50% |
| Lost Refrigerant GWP100 | lb CO ₂ e | 104,479 | 52,240 | -50% |
| Lost Refrigerant GWP20 | lb CO ₂ e | 217,217 | 108,609 | -50% |
| Average Leakage Rate | lb/yr | 3.34 | 1.67 | -50% |
| Avg Annual Leaked Refrigerant GWP100 | lb CO ₂ e | 6,965 | 3,483 | -50% |
| Avg Annual Leaked Refrigerant GWP20 | lb CO ₂ e | 14,481 | 7,241 | -50% |
| Heat Pump COP | COP | 3 | 3 | 0% |
| Electric Fraction of Heat | kWh/yr | 43,962 | 10,991 | -75% |
| HP Emission per kWh GWP100 | lb CO ₂ e/kWh | 0.0528 | 0.1056 | 100% |
| HP Emission per kWh GWP100 | g CO ₂ e/kWh | 24.0 | 47.9 | 100% |
| HP Emission per kWh GWP20 | lb CO ₂ e/kWh | 0.1098 | 0.2196 | 100% |
| HP Emission per kWh GWP20 | g CO ₂ e/kWh | 49.8 | 99.6 | 100% |

| Gas to Heat Pump EUI Correction | |
|---------------------------------|-------|
| Original EUI | 30.0 |
| EUI Space Heat Fraction | 50% |
| Space Heat EUI | 15 |
| Gas Efficiency | 90% |
| Heat Demand EUI | 13.50 |
| Heat Pump COP | 2.0 |
| Heat Pump EUI | 6.8 |
| New Building EUI | 21.8 |
| New Heating Fraction | 31% |

| eGRID Subregion Lookup | | EF |
|------------------------|-------|--------------------------|
| Zip Code | 83702 | lb CO ₂ e/MWh |
| Subregion 1 | NWPP | 936 |
| Subregion 2 | -- | -- |
| Subregion 3 | -- | -- |

<https://www.epa.gov/egrid/power-profiler/>



Operational and Embodied Emissions Estimator

| PV System Inputs | | Units | Case 1 | Case 2 | U% |
|---|--------------------------------------|-------|---|---|------|
| Fraction of EUI covered by PV | % | | 0% | 0% | 0% |
| PV Gen per kW | kWh/yr | | 1,000 | 1,000 | 0% |
| PV Size | kW | | 0.0 | 0.0 | 0% |
| Upfront PV Emission per kW | lb CO ₂ e/kW | | 1,323 | 1,323 | 0% |
| Upfrong PV Emission Total | lb CO ₂ e | | 0 | 0 | 0% |
| PV Lifespan | Years | | 30 | 30 | 0% |
| Total PV Generation | kWh | | 0 | 0 | 0% |
| PV Emission per kWh | lb CO ₂ e/kWh | | 0.0000 | 0.0000 | 0% |
| PV Emission per kWh | g CO ₂ e/kWh | | 0.0 | 0.0 | 0% |
| Battery System Inputs | | Units | Case 1 | Case 2 | U% |
| Days of Storage | Days | | 0 | 0 | 0% |
| Average Daily Demand | kWh/day | | 241 | 120 | -50% |
| Average Power Draw | Watts | | 10,037 | 5,019 | -50% |
| Storage Capacity | kWh | | 0 | 0 | 0% |
| Storage Emission per kWh | lb CO ₂ e/kWh | | 165 | 165 | 0% |
| Storage Emission Total | lb CO ₂ e | | 0 | 0 | 0% |
| Building Envelope Inputs | | Units | Case 1 | Case 2 | U% |
| Number of Floors | Stories | | 3 | 3 | 0% |
| Roof Area | ft ² | | 3,333 | 3,333 | 0% |
| Slab Area | ft ² | | 3,333 | 3,333 | 0% |
| Net Wall Area | ft ² | | 5,889 | 5,889 | 0% |
| Window to Wall Ratio (WWR) | % | | 15% | 15% | 0% |
| Window Area | ft ² | | 1,039 | 1,039 | 0% |
| Triple Pane Windows | Y/N | | NO | YES | 0% |
| Glass Upgrade Emissions | lb CO ₂ e | | 0 | 2,773 | 100% |
| Roof Insulation Upgrade | R-Value | | 0 | 0 | 0% |
| Roof Insulation Type | Select | | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | 0% |
| Roof Insulation Upgrade Emissions | lb CO ₂ e | | 0 | 0 | 0% |
| Slab Insulation Upgrade | R-Value | | 0 | 0 | 0% |
| Slab Insulation Type | Select | | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | 0% |
| Slab Insulation Upgrade Emissions | lb CO ₂ e | | 0 | 0 | 0% |
| Wall Insulation Upgrade | R-Value | | 0 | 0 | 0% |
| Wall Insulation Type | Select | | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | 0% |
| Wall Insulation Upgrade Emissions | lb CO ₂ e | | 0 | 0 | 0% |
| Total Envelope Upgrade Emissions | lb CO ₂ e | | 0 | 2,773 | 100% |
| Whole Building Emissions | | Units | Case 1 | Case 2 | U% |
| Output from BEAM or 3rd Party (no upgrades) | lb CO ₂ e/ft ² | | 30 | 30 | 0% |
| Total Building Emission Before Upgrades | lb CO ₂ e | | 300,000 | 300,000 | 0% |

Operational and Embodied Emissions Estimator


| | | | | |
|-----------------------------------|----------------------|--|--|------|
| Slab Insulation Type | Select | avg [BEAM Avg US & CA] | avg [BEAM Avg US & CA] | |
| Slab Insulation Upgrade Emissions | lb CO ₂ e | 0 | 0 | 0% |
| Wall Insulation Upgrade | R-Value | | | 0% |
| Wall Insulation Type | Select | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | |
| Wall Insulation Upgrade Emissions | lb CO ₂ e | 0 | 0 | 0% |
| Total Envelope Upgrade Emissions | lb CO ₂ e | 0 | 2,773 | 100% |

| Whole Building Emissions | Units | Case 1 | Case 2 | |
|---|--------------------------------------|---------|---------|----|
| Output from BEAM or 3rd Party (no upgrades) | lb CO ₂ e/ft ² | 30 | 30 | 0% |
| Total Building Emission Before Upgrades | lb CO ₂ e | 300,000 | 300,000 | 0% |

| Simple Graph Inputs | Case 1 | Case 2 | |
|---------------------------------------|--------|--------|------|
| Years | 10.0 | 10.0 | 0% |
| Name | EUI 30 | EUI 15 | |
| Embodied Building Emissions | 136.1 | 136.1 | 0% |
| Enclosure Upgrades | 0.0 | 1.3 | 100% |
| PV | 0.0 | 0.0 | 0% |
| Battery/Storage | 0.0 | 0.0 | 0% |
| Heat Pump Equipment | 7.0 | 3.5 | -50% |
| Heat Pump Refrigerant Leakage | 65.7 | 32.9 | -50% |
| 10 Year Operational Carbon | 373.4 | 186.7 | -50% |
| Total Embodied and Operational Carbon | 582.3 | 360.4 | -38% |
| Operational % | 64.1% | 51.8% | -19% |


| Cumulative Emissions Forecast Graph Inputs | Case 1 | Case 2 | |
|--|----------------------|-----------|-------|
| Region | NWPP | NWPP | |
| Camium Emission Factor | lrmr_co2e | lrmr_co2e | |
| Refrigerant GWP | GWP20 | GWP20 | |
| Avg Annual Leaked Refrigerant Emissions | kg CO ₂ e | 6,570 | 3,285 |

Operational and Embodied Tonnes CO₂e




EUI 30

Case 1
Cumulative Emissions tonnes CO₂e




EUI 15


Case 2
Cumulative Emissions tonnes CO₂e



Operational Carbon Boundaries



Operational Carbon eGRID subregions Grid Interconnection & Systems Thinking



Subregions, unlike states, are defined using the transmission, distribution and utility service territories of power plants and therefore don't follow traditional geographic state boundaries.

Operational Carbon eGRID subregions



Photo by Dennis Schroeder, NREL 23201

Greenhouse Gas Emissions Accounting in Buildings

Building operations in the United States account for about 70% of electricity use, about 40% of the total U.S. primary energy consumption,¹ and about 30% of greenhouse gas (GHG) emissions.² Carbon dioxide (CO₂) emissions from building energy use and embodied emissions accounted for about 37% of global CO₂ emissions in 2020.³ Thus, accurate GHG emissions accounting is critical to inform decisions for emissions reduction. This fact sheet provides an introduction to GHG emissions accounting for operation of buildings including equipment replacements and operational material purchases. It does not include embodied GHG emissions in existing buildings or from major retrofit construction activities.

What are operational activities that result in emissions and where are the opportunities to reduce emissions from commercial buildings?

The majority of GHG emissions from building activities come from combustion of fossil fuels for energy, either remotely for generation of electricity or on-site for heat and power generation. Carbon dioxide, methane, and nitrous oxide are all GHGs associated with combustion. Methane can also be released to the atmosphere from leakage in pipes, valves, and equipment. Refrigerants are very powerful GHGs and can leak from refrigeration and heat pump equipment during installation, maintenance, and operation. Annual refrigerant leakage varies significantly and is most often estimated to be between 1% and 10% of the total system refrigerant charge, but can be much higher if there is a catastrophic failure in the system.⁴




Figure 1. Example operational activities that impact emissions, representing an 87% reduction in GHG emissions. Data are for demonstration purposes only for a supermarket. Equipment purchases can refer to furniture purchases such as desks, chairs, and partitions for commercial building use.

“National vs. Regional vs. Utility: Emission factors can be calculated for different locations: national, regional, or utility.


The most common regional values are based on the 26 eGRID subregions defined by the EPA. State-level emission factors may not be good representations of local emissions and are not recommended.”

¹ EIA 2021. Monthly Energy Review, preliminary data for 2020. <https://www.eia.gov/totalenergy/data/monthly/>. US Energy Information Administration Washington DC.
² US EPA 2021. Sources of Greenhouse Gas Emissions. <https://www.epa.gov/ghgemissions/sources-greenhouse-gas-emissions>. Washington DC.
³ UNFPA 2021. Global ABC 2021 Global status report.
⁴ Integral Group. 2020. Refrigerants + Fluorochemical Impacts: A Best Practice Guide! <https://www.integralgroup.com/news/refrigerants-environmental-impacts/>. See Appendix A.4 for more data on leakage rates for HVAC systems.

Operational Carbon Boundaries




CO₂ equivalent total output emission rate (lb/MWh)
by state, 2020



Sort A to Z Sort by Amount


US: 822.62 (lb/MWh)



Operational Carbon Boundaries




CO₂ equivalent total output emission rate (lb/MWh)
by eGRID subregion, 2020



Sort A to Z Sort by Amount

US: 822.62 (lb/MWh)



Operational Carbon ASHRAE 189.1-2017 Addendum aa Upstream & Transmission Adjustment



© ASHRAE. Per international copyright law, additional reproduction, distribution, or transmission in either print or digital form is not permitted without ASHRAE's prior written permission.

**ANSI/ASHRAE/ICC/USGBC/IES Addendum aa to
ANSI/ASHRAE/ICC/USGBC/IES Standard 189.1-2017**

Standard for the Design of High-Performance Green Buildings

Except Low-Rise
Residential Buildings

The Complete Technical Content of the International Green Construction Code®

Approved by the ASHRAE Standards Committee on June 26, 2020; by the ASHRAE Board of Directors on July 1, 2020; by the International Code Council on June 1, 2020; by the U.S. Green Building Council on June 3, 2020; by the Illuminating Engineering Society on July 1, 2020; and by the American National Standards Institute on July 31, 2020.

These addenda were approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (www.ashrae.org/continuous-maintenance).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305, telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in the United States and Canada), or e-mail: orders@ashrae.org. For reprint permission, go to www.ashrae.org/permissions.

© 2020 ASHRAE ISSN 1041-2336



IGCC®

INTERNATIONAL GREEN CONSTRUCTION CODE®

A Comprehensive Solution for High-Performance Buildings

A Member of the International Code Family™

2021

POWERED BY
ANSI/ASHRAE/ICC/USGBC/IES 189.1-2020
Standard for the Design of High-Performance
Green Buildings Except Low-Rise Residential Buildings

Operational Carbon IgCC 2021

TABLE 701.5.2 (TABLE 7.5.2)
SOURCE ENERGY CONVERSION FACTORS AND CO₂e EMISSIONS FACTORS

| ENERGY FORM | SOURCE ENERGY CONVERSION FACTOR | CO ₂ e EMISSIONS FACTOR | |
|--|---------------------------------|------------------------------------|--------|
| | | lb/MWh | kg/MWh |
| Fuels Used Directly in Building | | | |
| Natural gas | 1.09 | 681 | 309 |
| LPG or propane | 1.15 | 651 | 295 |
| Fuel oil (residual) | 1.19 | 738 | 335 |
| Fuel oil (distillate) | 1.19 | 715 | 324 |
| Coal | 1.05 | 892 | 405 |
| Gasoline | 1.19 | 744 | 337 |
| Other fuels not specified in this table | 1.05 | 892 | 405 |
| Imported Electricity and Exported Renewable Electricity | | | |
| AKGD—ASCC Alaska Grid | 2.52 | 1580 | 717 |
| AKMS—ASCC Miscellaneous | 1.21 | 738 | 335 |
| AZNM—WECC Southwest | 2.75 | 1496 | 679 |
| CAMX—WECC California | 1.94 | 957 | 434 |
| ERCT—ERCOT All | 2.58 | 1529 | 694 |
| FRCC—FRCC All | 2.97 | 1601 | 726 |
| HIMS—HICC Miscellaneous | 2.86 | 1717 | 779 |
| HIOA—HICC Oahu | 3.83 | 2460 | 1116 |
| MROE—MRO East | 3.08 | 2337 | 1060 |
| MROW—MRO West | 2.50 | 1686 | 765 |
| NEWE—NPCC New England | 2.87 | 1024 | 464 |
| NWPP—WECC Northwest | 1.39 | 936 | 425 |
| NYCW—NPCC NYC/Westchester | 2.92 | 1054 | 469 |
| NYLI—NPCC Long Island | 2.90 | 1600 | 726 |
| NYUP—NPCC Upstate NY | 1.97 | 540 | 245 |
| RFCE—RFC East | 3.05 | 1156 | 524 |
| RFCM—RFC Michigan | 3.06 | 1806 | 819 |
| RFCW—RFC West | 3.14 | 1757 | 797 |
| RMPA—WECC Rockies | 2.33 | 1829 | 830 |
| SPNO—SPP North | 2.67 | 1851 | 840 |
| SPSO—SPP South | 2.46 | 1737 | 788 |
| SRMV—SERC Mississippi Valley | 2.95 | 1421 | 645 |
| SRMW—SERC Midwest | 3.20 | 2234 | 1014 |
| SRSO—SERC South | 3.04 | 1651 | 749 |
| SRTV—SERC Tennessee Valley | 3.02 | 1677 | 761 |
| SRVC—SERC Virginia/Carolina | 3.11 | 1255 | 569 |
| All other electricity | 2.64 | 1418 | 643 |
| District Thermal Energy | | | |
| Chilled water | 0.63 | 339 | 154 |
| Steam | 1.83 | 1145 | 519 |
| Hot water | 1.73 | 1081 | 491 |

Informative Note: Values in this table represent averages for the United States and include both direct and indirect emissions. The source energy conversion factors are based on noncombustible renewable energy having a zero heat rate. The carbon dioxide equivalent emissions of methane (CH₄) and nitrous oxide (N₂O) are based on their GWP for a 20 year time horizon. Other assumptions are documented in Informative Appendix J.

<https://codes.iccsafe.org/content/IGCC2021P1/>

TABLE J102.1 (TABLE J2-1)
DIRECT AND INDIRECT EMISSIONS FROM FOSSIL FUELS USE^a

(Source: Michael Deru and Paul Torcellini, Source Energy and Emission Factors for Energy Use in Buildings, National Renewable Energy Laboratory, Technical Report NREL/TP-550-38617, Revised June 2007, except as noted below.)

| FUEL | CARBON DIOXIDE (CO ₂) | METHANE (CH ₄) | NITROUS OXIDE (N ₂ O) | CO ₂ e |
|---|-----------------------------------|----------------------------|----------------------------------|-------------------|
| Direct Emissions (lb/MWh of input) | | | | |
| Natural gas (at the building) | 412.14 | 0.0084 | 0.0084 | 415 |
| Natural gas (at the power plant) | 412.14 | 0.0084 | 0.0084 | 415 |
| LPG (propane) | 494.93 | 0.0081 | 0.0366 | 505 |
| Residual fuel oil | 581.98 | 0.0053 | 0.0027 | 583 |
| Distillate fuel oil | 560.88 | 0.0057 | 0.0029 | 562 |
| Coal ^b | 738.26 | 0.0323 | 0.1033 | 768 |
| Gasoline | 560.88 | 0.0057 | 0.0029 | 562 |
| Biomass ^c | 355.04 | 0.0243 | 0.0414 | 368 |
| Indirect Emissions (lb/MWh of input) | | | | |
| Natural gas (at the building) ^d | 39.19 | 2.7000 | 0.0008 | 266 |
| Natural gas (at the power plant) ^d | 39.19 | 2.1000 | 0.0008 | 216 |
| LPG or propane | 76.86 | 0.8174 | 0.0014 | 146 |
| Residual fuel oil | 81.48 | 0.8695 | 0.0015 | 155 |
| Distillate fuel oil | 80.69 | 0.8585 | 0.0015 | 153 |
| Coal ^b | 26.16 | 1.1649 | 0.0005 | 124 |
| Gasoline | 95.54 | 1.0168 | 0.0018 | 181 |
| Biomass ^c | 16.60 | 0.0199 | 0.00008 | 18 |
| Total Emissions (lb/MWh of input) | | | | |
| Natural gas (at the building) | 451.33 | 2.7084 | 0.0092 | 681 |
| Natural gas (at the power plant) | 451.33 | 2.1084 | 0.0092 | 631 |
| LPG or propane | 571.79 | 0.8255 | 0.0380 | 651 |
| Residual fuel oil | 663.46 | 0.8748 | 0.0042 | 738 |
| Distillate fuel oil | 641.56 | 0.8642 | 0.0044 | 715 |
| Coal ^b | 764.42 | 1.1972 | 0.1038 | 892 |
| Gasoline | 656.41 | 1.0225 | 0.0047 | 744 |
| Biomass ^c | 371.64 | 0.0442 | 0.0414 | 386 |

a. The NREL data in this report were derived from the United States Life Cycle Inventory (LCI) Database maintained by NREL.

b. The NREL report gives values for various types of coal, but bituminous is used for this analysis because it is most common form in the United States.


c. Values for biomass were not reported in the NREL document. Figures in this table were derived separately from EIA data and information from the California Air Resources Board (CARB). The cumulative net emissions for the 20 year period are calculated by subtracting the estimated counterfactual emissions.

d. Indirect methane emissions for natural gas are based on total losses of 1.4% for gas delivered to power plants and 1.8% for gas delivered to buildings, per Table ES-1 of Life Cycle Analysis of Natural Gas Extraction and Power Generation, August 30, 2016, DOE/NETL-2015/1714.

TABLE J201.2 (TABLE J2-2)
GLOBAL WARMING POTENTIAL (UNITLESS MULTIPLIERS)
(SOURCE: IPCC 2013, AR4 WITHOUT CLIMATE CARBON FEEDBACKS)


| | CARBON DIOXIDE (CO ₂) | METHANE (CH ₄) | NITROUS OXIDE (N ₂ O) |
|-----------------------------|-----------------------------------|----------------------------|----------------------------------|
| 20 year cumulative forcing | 1 | 84 | 264 |
| 100 year cumulative forcing | 1 | 28 | 265 |

Operational Carbon Upstream & Transmission Adjustment



Emission Factors

Marginal Emissions Concept




Emission Factors

Marginal Emissions




CO₂ equivalent non-baseload output emission rate (lb/MWh)
by state, 2020



Sort A to Z Sort by Amount


US: 1,407 (lb/MWh)



Emission Factors


Average vs Marginal or Non-Baseload

Use Short Term
Marginal With
Caution!



Emission Factors


Forward Looking or Long Run Emissions Rates



A long-run marginal emission rate is the rate of emissions that would be either induced or avoided by a long-term (i.e., more than several years) change in electrical demand, incorporating both the operational and structural consequences of the change. It is therefore distinct from the more commonly known short-run marginal, which treats grid assets as fixed.


Boundary Conditions Imports/Exports & Emissions Leakage

⚡ ELECTRICITY MAPS




Boundary Conditions Imports/Exports & Emissions Leakage

⚡ ELECTRICITY MAPS



**Energy Use Intensity
& Operational Carbon**


2,000 ft² NWPP Region



eGRID Subregion NWPP 0.936 lb CO₂e/kWh (425 kg/MWh)

**Energy Use Intensity
& Load Reduction**

2,000 ft² NWPP Region



Heat Pump Embodied Carbon Load Reduction Benefits Equipment



3.5 ton
Indoor Unit **172 lb**
Outdoor Unit **283 lb**
≈1,800 lb/CO₂e



1 ton
Indoor Unit **93 lb**
Outdoor Unit **129 lb**
≈600 lb/CO₂e

Average MEP equipment is 9kgCO₂e/kg (excluding refrigerant).

Heat Pump Embodied Carbon Load Reduction Benefits Refrigerant



3.5 ton

R-410A 13.25 lb

27,659 lb/CO₂e GWP100

57,505 lb/CO₂e GWP20



1 ton

R-410A 3.56 lb

7,432 lb/CO₂e GWP100

15,450 lb/CO₂e GWP20

R410A 2,088 GWP100 & 4,340 GWP20

**PV Embodied Carbon
Load Reduction Benefits**

2,000 ft² NWPP Region



**Typical
Home**

17,585 kWh/yr

÷

1,000 kWh/yr per kW

17.6
kW



**Passive
House**


8,793 kWh/yr

÷

1,000 kWh/yr per kW

8.8
kW

**Embodied Carbon
Net Zero PV System**



8.8kW
11,932 lb CO₂e
(5,412 kg)



17.6 kW
23,863 lb CO₂e
(10,824 kg)

615 kgCO₂/kWp

Embodied Carbon Context

1 kW = 615 kg CO₂e Upfront Emissions

1,000 kWh/yr x 20 years = 20,000 kWh

615 kg CO₂e ÷ 20,000 kWh = 31 gCO₂e/kWh


NWPP = 425 gCO₂e/kWh

Arranged by decreasing **median**
(gCO₂eq/kWh) values.

| Technology | Min. | Median | Max. |
|--|-----------|-----------|-------------------|
| Currently commercially available technologies | | | |
| Coal – PC | 740 | 820 | 910 |
| Gas – combined cycle | 410 | 490 | 650 |
| Biomass – Dedicated | 130 | 230 | 420 |
| Solar PV – Utility scale | 18 | 48 | 180 |
| Solar PV – rooftop | 26 | 41 | 60 |
| Geothermal | 6.0 | 38 | 79 |
| Concentrated solar power | 8.8 | 27 | 63 |
| Hydropower | 1.0 | 24 | 2200 ¹ |
| Wind Offshore | 8.0 | 12 | 35 |
| Nuclear | 3.7 | 12 | 110 |
| Wind Onshore | 7.0 | 11 | 56 |


Seasonal Storage Context Heating Demand Reduction

Code



Jan + Dec Heating
4,000 kWh

Passive House




Jan + Dec Heating
600 kWh

2,000 ft² Boise, ID


Seasonal Storage Context Heating Demand Reduction

Code



Jan + Dec Heating Deficit Code vs PH
3,400 kWh

Passive House



Tesla Powerwall 13.5 kWh Storage
 $3,400/13.5 = 252$ Powerwalls


$\approx 600,000$ lb CO₂e

2,000 ft² Boise, ID

Energy Use Intensity & Operational Carbon

1 Year Net-Zero 2,000 ft² NWPP Subregion


Operational and Embodied Tonnes CO₂e



eGRID Subregion NWPP 0.936 lb CO₂e/kWh (425 kg/MWh)


Energy Use Intensity & Operational Carbon

10 Year Net-Zero 2,000 ft² NWPP Subregion



eGRID Subregion NWPP 0.936 lb CO₂e/kWh (425 kg/MWh)

Operational Carbon Future Emissions Scenarios




Energy Use Intensity & Operational Carbon

2050 Forecasts 2,000 ft² NWPP Subregion GWP20

EUI 30


Cumulative Emissions tonnes CO₂e



Refrigerant Emissions Embodied Carbon Mid-Case
95% by 2035 95% by 2050 eGRID-2020

EUI 15



Cumulative Emissions tonnes CO₂e



Refrigerant Emissions Embodied Carbon Mid-Case
95% by 2035 95% by 2050 eGRID-2020


Energy Use Intensity & Operational Carbon

2050 Forecasts 2,000 ft² NWPP Subregion GWP100



Energy Use Intensity & Operational Carbon

1 Year Net-Zero 2,000 ft² RFCW Subregion




eGRID Subregion NWPP 1.757 lb CO₂e/kWh (425 kg/MWh)

Energy Use Intensity & Operational Carbon

10 Year Net-Zero 2,000 ft² RFCW Subregion

Operational and Embodied Tonnes CO₂e




eGRID Subregion NWPP 1.757 lb CO₂e/kWh (425 kg/MWh)

Energy Use Intensity & Operational Carbon


2050 Forecasts 2,000 ft² RFCW Subregion GWP20

EUI 30
Cumulative Emissions tonnes CO₂e



- Refrigerant Emissions
- Embodied Carbon
- Mid-Case
- 95% by 2035
- 95% by 2050
- eGRID-2020

EUI 15
Cumulative Emissions tonnes CO₂e




- Refrigerant Emissions
- Embodied Carbon
- Mid-Case
- 95% by 2035
- 95% by 2050
- eGRID-2020

Energy Use Intensity & Operational Carbon

2050 Forecasts 2,000 ft² RFCW Subregion GWP100

EUI 30


Cumulative Emissions tonnes CO₂e



Refrigerant Emissions Embodied Carbon Mid-Case
95% by 2035 95% by 2050 eGRID-2020

EUI 15

Cumulative Emissions tonnes CO₂e



Refrigerant Emissions Embodied Carbon Mid-Case
95% by 2035 95% by 2050 eGRID-2020

Thank you!




OC/EC estimator will be available for download presently at <https://passivehouseaccelerator.com/>

| | | | | |
|-----------------------------------|----------------------|---|---|------|
| Slab Insulation Type | Select | avg [BEAM Avg US & CA] | avg [BEAM Avg US & CA] | |
| Slab Insulation Upgrade Emissions | lb CO ₂ e | 0 | 0 | 0% |
| Wall Insulation Upgrade | R-Value | 0 | 0 | 0% |
| Wall Insulation Type | Select | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | EPS foam board / R 4.0/inch avg [BEAM Avg US & CA] | |
| Wall Insulation Upgrade Emissions | lb CO ₂ e | 0 | 0 | 0% |
| Total Envelope Upgrade Emissions | lb CO ₂ e | 0 | 2,773 | 100% |

| Whole Building Emissions | Units | Case 1 | Case 2 | |
|---|--------------------------------------|---------|---------|----|
| Output from BEAM or 3rd Party (no upgrades) | lb CO ₂ e/ft ² | 30 | 30 | 0% |
| Total Building Emission Before Upgrades | lb CO ₂ e | 300,000 | 300,000 | 0% |

| Simple Graph Inputs | Case 1 | Case 2 | |
|---------------------------------------|--------|--------|------|
| Years | 10.0 | 10.0 | 0% |
| Name | EUI 30 | EUI 15 | |
| Embodied Building Emissions | 136.1 | 136.1 | 0% |
| Enclosure Upgrades | 0.0 | 1.3 | 100% |
| PV | 0.0 | 0.0 | 0% |
| Battery/Storage | 0.0 | 0.0 | 0% |
| Heat Pump Equipment | 7.0 | 3.5 | -50% |
| Heat Pump Refrigerant Leakage | 65.7 | 32.9 | -50% |
| 10 Year Operational Carbon | 373.4 | 186.7 | -50% |
| Total Embodied and Operational Carbon | 582.3 | 360.4 | -38% |
| Operational % | 64.1% | 51.8% | -19% |


| Cumulative Emissions Forecast Graph Inputs | Case 1 | Case 2 | | |
|--|----------------------|-----------|-------|------|
| Region | NWPP | NWPP | | |
| Cambium Emission Factor | lmer_co2e | lmer_co2e | | |
| Refrigerant GWP | GWP20 | GWP20 | | |
| Avg Annual Leaked Refrigerant Emissions | kg CO ₂ e | 6,570 | 3,285 | -50% |



Supplemental Slides For OC/EC Estimator Reference

Inventory of US Greenhouse Gas Emissions and Sinks

Millions of Tons of CO₂ Emissions by Sector and Type




“This book is principally concerned with the emergency of the nearly 75% of greenhouse-gas emissions related to the US energy system, which accounts for the overwhelming majority of our emissions (the US is representative of the global problem, so throughout this book, while we focus on the US, our analysis is usually a reasonable proxy for the entire globe).¹ Other emissions come from the agricultural sector (around 12%), land use and forestry (7%), and industrial non–energy use emissions (7%). Mobilizing to address climate change as suggested in this book would also address much of the industrial non-energy emissions, and a little of the other two, as well. Decarbonizing America’s energy supply is about 85% of what we need to do. I have to believe that if we commit to solving 85% of the problem, the smart and passionate people working on the other 15% will do their part, too. For this reason, emissions unrelated to energy will receive only periodic mention throughout the rest of the book.

Inventory of US Greenhouse Gas Emissions and Sinks

U.S. Greenhouse Gas Emissions by Gas, 2020


Emissions in million metric tons of carbon dioxide equivalent



● Carbon dioxide (78.8%) ● Methane (10.9%)
● Nitrous oxide (7.1%) ● Fluorinated gases (3.2%)

Source: U.S. EPA's Inventory of U.S. Greenhouse Gas Emissions and Sinks: 1990-2020.
<https://www.epa.gov/ghgemissions/inventory-us-greenhouse-gas-emissions-and-sinks>

Context



“Whole-building energy efficiency provides a strong foundation for electrification because it reduces a building’s thermal load and peak demand.

A smaller overall heating load makes electrification more cost effective by reducing HVAC size, and a building’s demand flexibility and resilience improve when a constant indoor temperature can be maintained for a longer period of time.

As electrification increases electric load during peak times, it may raise carbon emissions for some periods when carbon-intensive units, such as coal, are used for marginal generation.

A lower peak demand reduces these marginal emissions.”

Context

“If you think about how energy is consumed around the world, people think it’s consumed in the form of electricity, but in fact it’s mostly consumed in the form of heat...If you want to decarbonize the world, you need to decarbonize buildings and industry. That means you need to decarbonize heat...”

Noel Bakhtian, executive director of Berkeley Lab’s Energy Storage Center.

Seasonal Load Summer to Winter Peak

www.nature.com/scientificreports

scientific reports


OPEN

Inefficient Building Electrification Will Require Massive Buildout of Renewable Energy and Seasonal Energy Storage

Jonathan J. Buonocore^{1,5✉}, Parichehr Salimifard^{2,3}, Zeyneb Magavi⁴ & Joseph G. Allen³

Building electrification is essential to many full-economy decarbonization pathways. However, current decarbonization modeling in the United States (U.S.) does not incorporate seasonal fluctuations in building energy demand, seasonal fluctuations in electricity demand of electrified buildings, or the ramifications of this extra demand for electricity generation. Here, we examine historical energy data in the U.S. to evaluate current seasonal fluctuation in total energy demand and management of seasonal fluctuations. We then model additional electricity demand under different building electrification scenarios and the necessary increases in wind or solar PV to meet this demand. We found that U.S. monthly average total building energy consumption varies by a factor of 1.6×—lowest in May and highest in January. This is largely managed by fossil fuel systems with long-term storage capability. All of our building electrification scenarios resulted in substantial increases in winter electrical demand, enough to switch the grid from summer to winter peaking. Meeting this peak with renewables would require a 28× increase in January wind generation, or a 303× increase in January solar, with excess generation in other months. Highly efficient building electrification can shrink this winter peak—requiring 4.5× more generation from wind and 36× more from solar.

Check for updates



Emission Factors Boundary Conditions



Photo by Dennis Schroeder, NREL 23201

Greenhouse Gas Emissions Accounting in Buildings

Building operations in the United States account for about 70% of electricity use, about 40% of the total U.S. primary energy consumption,¹ and about 30% of greenhouse gas (GHG) emissions.² Carbon dioxide (CO₂) emissions from building energy use and embodied emissions accounted for about 37% of global CO₂ emissions in 2020.³ Thus, accurate GHG emissions accounting is critical to inform decisions for emissions reduction. This fact sheet provides an introduction to GHG emissions accounting for operation of buildings including equipment replacements and operational material purchases. It does not include embodied GHG emissions in existing buildings or from major retrofit construction activities.

What are operational activities that result in emissions and where are the opportunities to reduce emissions from commercial buildings?

The majority of GHG emissions from building activities come from combustion of fossil fuels for energy, either remotely for generation of electricity or on-site for heat and power generation. Carbon dioxide, methane, and nitrous oxide are all GHGs associated with combustion. Methane can also be released to the atmosphere from leakage in pipes, valves, and equipment. Refrigerants are very powerful GHGs and can leak from refrigeration and heat pump equipment during installation, maintenance, and operation. Annual refrigerant leakage varies significantly and is most often estimated to be between 1% and 10% of the total system refrigerant charge, but can be much higher if there is a catastrophic failure in the system.⁴




Figure 1. Example operational activities that impact emissions, representing an 87% reduction in GHG emissions. Data are for demonstration purposes only for a supermarket. Equipment purchases can refer to furniture purchases such as desks, chairs, and partitions for commercial building use.

Where can I find emission factors?

| Source | Energy /Fuel | Scope | Time Scale | Region | Background Data Source | GWP-Year |
|---|--------------------------------|---|---|--|---|----------------|
| EPA eGRID ⁶ | Electricity | Combustion to end use | Annual average and non-baseload | U.S., NERC regions, eGRID subregions, state, balancing areas | CAMD, EIA-860, EIA-923 (2019) | AR4, 100-yr |
| Green-e ⁷ | Electricity | Combustion to end use for residuals | Annual average | U.S., eGRID subregions | eGRID, Green-e certified sales | AR4 100-yr |
| Edison Electric Institute GHG database ⁸ | Electricity | Combustion to end use for total and residuals | Annual average | Utility (43% of country) | Utility data, (2018 and 2019) | AR4 100-yr |
| ASHRAE Standard 105-2021 | Electricity & fuels | Full life cycle | Annual average and non-baseload | U.S., eGRID subregions | eGRID plus (2014, 2019) | 20-yr & 100-yr |
| ASHARE Standard 189.1-2020 | Electricity & fuels | Full life cycle | Annual average | U.S., eGRID subregions | EIA 2017 | 20-yr & 100-yr |
| Watttime | Electricity | Combustion to end use | 15 minute marginal | Balancing areas | Real time | AR4, 100-yr |
| Cambium, NREL ⁹ | Electricity | Future projections | 15 minute, hourly, average and marginal | U.S., regional assessment zones, balancing area | Simulated future energy scenarios with 2012 weather | AR4, 100-yr |
| EPA ¹⁰ | Fuels, refrigerants and others | Combustion or direct atmospheric release | Event-based | U.S. | Multiple (see resource documentation) | AR4, 100-yr |

¹ EIA 2021. Monthly Energy Review, preliminary data for 2020. <https://www.eia.gov/totalenergy/data/monthly>. US Energy Information Administration Washington DC.
² US EPA 2021. Sources of Greenhouse Gas Emissions. <https://www.epa.gov/ghgemissions/sources-greenhouse-gas-emissions>. Washington DC.
³ UNFPA, IFA 2021. Global ABC 2021 Global status report.
⁴ Integral Group. 2020. Refrigerants + Fluorochemicals Impacts: A Best Practice Guide. <https://www.integralgroup.com/news/refrigerants-environmental-impacts/>. See Appendix A.4 for more data on leakage rates for HVAC systems.

Emission Factors Boundary Conditions



Photo by Dennis Schroeder, NREL 23201

Greenhouse Gas Emissions Accounting in Buildings

Building operations in the United States account for about 70% of electricity use, about 40% of the total U.S. primary energy consumption,¹ and about 30% of greenhouse gas (GHG) emissions.² Carbon dioxide (CO₂) emissions from building energy use and embodied emissions accounted for about 37% of global CO₂ emissions in 2020.³ Thus, accurate GHG emissions accounting is critical to inform decisions for emissions reduction. This fact sheet provides an introduction to GHG emissions accounting for operation of buildings including equipment replacements and operational material purchases. It does not include embodied GHG emissions in existing buildings or from major retrofit construction activities.

What are operational activities that result in emissions and where are the opportunities to reduce emissions from commercial buildings?

The majority of GHG emissions from building activities come from combustion of fossil fuels for energy, either remotely for generation of electricity or on-site for heat and power generation. Carbon dioxide, methane, and nitrous oxide are all GHGs associated with combustion. Methane can also be released to the atmosphere from leakage in pipes, valves, and equipment. Refrigerants are very powerful GHGs and can leak from refrigeration and heat pump equipment during installation, maintenance, and operation. Annual refrigerant leakage varies significantly and is most often estimated to be between 1% and 10% of the total system refrigerant charge, but can be much higher if there is a catastrophic failure in the system.⁴




Figure 1. Example operational activities that impact emissions, representing an 87% reduction in GHG emissions. Data are for demonstration purposes only for a supermarket. Equipment purchases can refer to furniture purchases such as desks, chairs, and partitions for commercial building use.

“National vs. Regional vs. Utility: Emission factors can be calculated for different locations: national, regional, or utility.

The most common regional values are based on the 26 eGRID subregions defined by the EPA. State-level emission factors may not be good representations of local emissions and are not recommended.”

¹ EIA 2021. Monthly Energy Review, preliminary data for 2020. <https://www.eia.gov/totalenergy/data/monthly>. US Energy Information Administration Washington DC.
² US EPA 2021. Sources of Greenhouse Gas Emissions. <https://www.epa.gov/ghgemissions/sources-greenhouse-gas-emissions>. Washington DC.
³ UNFCCC 2021. Global ABC 2021 Global status report.
⁴ Integral Group. 2020. Refrigerants + Fluorochemical Impacts: A Best Practice Guide. <https://www.integralgroup.com/news/refrigerants-environmental-impacts/>. See Appendix A.4 for more data on leakage rates for HVAC systems.

Emission Factors Boundary Conditions



**THE EMISSIONS & GENERATION
RESOURCE INTEGRATED DATABASE**
eGRID Technical Guide with Year 2020 Data



Office of Atmospheric Programs
Clean Air Markets Division

3.4.2 eGRID Subregion

eGRID subregions are identified and defined by EPA and were developed as a compromise between NERC regions (which EPA felt were too big) and balancing authorities (which EPA felt were generally too small). Using NERC regions and balancing authorities as a guide, the subregions were defined to limit the import and export of electricity in order to establish an aggregated area where the determined emission rates most accurately matched the generation and emissions from the plants within that subregion.

Emission Factors Boundary Conditions



Environmental Topics

Laws & Regulations

About EPA

Search 1/19/17 snapshot



Energy and the Environment

Contact Us Share

Energy and the Environment

Learn About Energy and the Environment

The Electricity System

Renewable Heating and Cooling

Measure Your Impact

Reduce Your Impact

Clean Energy Programs

Power Profiler

Greenhouse Gas Equivalencies Calculator

eGRID

How to use eGRID for Carbon Footprinting Electricity Purchases in Greenhouse Gas Emission Inventories

This paper provides and reviews recommendations regarding which year(s) of eGRID subregion GHG emissions factors to use for estimating Scopes 2 and 3 GHG emissions from electricity use under various conditions.

You will need Adobe Reader to view some of the files on this page. See [EPA's About PDF page](#) to learn more.

- [How to use eGRID for Carbon Footprinting Electricity Purchases in Greenhouse Gas Emission Inventories \(PDF\)](#) (22 pp, 537 K)

Emission Factors

eGRID Aggregation Level



“Choosing an aggregation level that is too large (for example, the entire U.S.) includes generation that is not relevant to the regional resource mix.

Conversely, an aggregation level that is too small (for example, EGC) may exclude generation that is relevant to the area.


Ideally, information about all of the interchanges of electricity between all of the utilities and all of the generators of electricity would be useful along with the generation data in creating output emission rates that account for the wholesale transactions between utilities and EGCs.

*However, in the absence of public availability of such information, the **eGRID subregion level data is generally considered the best generation based aggregation level that minimizes the import/export issues.** As discussed above, the eGRID subregion level does not eliminate the issue of imports of electricity from other areas to satisfy demand within the eGRID subregion. However, most or all of the system power in each eGRID subregion originates from within an eGRID subregion.”*

Emission Factors Upstream and Transmission Corrections

lb CO₂e/MWh

**NWPP
55% Emissions
Increase**



Emission Factors

Average vs Marginal



Photo by Dennis Schroeder, NREL 23201

Greenhouse Gas Emissions Accounting in Buildings

Building operations in the United States account for about 70% of electricity use, about 40% of the total U.S. primary energy consumption,¹ and about 30% of greenhouse gas (GHG) emissions.² Carbon dioxide (CO₂) emissions from building energy use and embodied emissions accounted for about 37% of global CO₂ emissions in 2020.³ Thus, accurate GHG emissions accounting is critical to inform decisions for emissions reduction. This fact sheet provides an introduction to GHG emissions accounting for operation of buildings including equipment replacements and operational material purchases. It does not include embodied GHG emissions in existing buildings or from major retrofit construction activities.

What are operational activities that result in emissions and where are the opportunities to reduce emissions from commercial buildings?

The majority of GHG emissions from building activities come from combustion of fossil fuels for energy, either remotely for generation of electricity or on-site for heat and power generation. Carbon dioxide, methane, and nitrous oxide are all GHGs associated with combustion. Methane can also be released to the atmosphere from leakage in pipes, valves, and equipment. Refrigerants are very powerful GHGs and can leak from refrigeration and heat pump equipment during installation, maintenance, and operation. Annual refrigerant leakage varies significantly and is most often estimated to be between 1% and 10% of the total system refrigerant charge, but can be much higher if there is a catastrophic failure in the system.⁴




Figure 1. Example operational activities that impact emissions, representing an 87% reduction in GHG emissions. Data are for demonstration purposes only for a supermarket. Equipment purchases can refer to furniture purchases such as desks, chairs, and partitions for commercial building use.

Average emission factors represent total emissions averaged over a set period, while **marginal emission factors** represent the emissions associated with the last generation source(s) used to meet an increase in demand.

Average emission factors are more accurate for carbon footprints while **marginal emission factors** may be appropriate for estimating carbon reductions from implementing energy efficiency measures.

¹ EIA 2021. Monthly Energy Review, preliminary data for 2020. <https://www.eia.gov/totalenergy/data/monthly>. US Energy Information Administration Washington DC.
² US EPA 2021. Sources of Greenhouse Gas Emissions. <https://www.epa.gov/ghgemissions/sources-greenhouse-gas-emissions>. Washington DC.
³ UNFPA, IFA 2021. Global ABC 2021 Global status report.
⁴ Integral Group. 2020. Refrigerants + Fluorochemical Impacts: A Best Practice Guide. <https://www.integralgroup.com/news/refrigerants-environmental-impacts/>. See Appendix A.4 for more data on leakage rates for HVAC systems.

Emission Factors

Average vs Marginal

Uncertainty in electricity emissions rates.

Emissions rates for electric utilities vary from year to year, depending on factors such as hydropower production. But perhaps more importantly, accounting for electricity emissions is the subject of considerable methodological debate.

On the one hand, SCL sources most of its electricity from low-carbon sources (hydropower dams and nuclear power plants), whereas Puget Sound Energy gets much of its energy from coal and natural gas plants—suggesting that electricity consumption in SCL’s service territory produces much lower emissions than in PSE’s.

Yet on the other hand, overall emissions across the generation portfolio of the entire Northwest Power Pool may be only minimally affected by the choice of putting new housing in SCL’s service territory. (After all, building new housing in SCL’s service territory doesn’t cause the region’s dams, nuclear plants, or wind farms to produce more electricity.)

The two very different methods of emissions accounting (averages for each utility vs. marginal emissions for the entire Northwest Power Pool) yield vastly different estimates for potential emissions reductions from housing location choices within King County. For this analysis, we develop high-end and low-end estimates of the potential emissions reductions due to different generation mixes with Seattle—but we recognize that emissions from electricity will remain uncertain and subject to debate.

Emission Factors

Average vs Marginal



THE EMISSIONS HIDDEN IN THE MARGINS

The difference between average and marginal emissions factors can be very large, and quite important. An average factor refers to the amount of emissions generated over a given time, divided by the amount of energy produced in that time. For example, the U.S. Pacific Northwest gets most of its electricity from hydropower, a low-emissions energy resource, and thus its average emissions factor is very low.

A marginal emissions factor refers to rate at which emissions would change with a small change to electricity load. Continuing the simplified Pacific Northwest example, imagine a time when hydropower is providing 75 percent of the region's power and gas-fired power plants are providing the remaining 25 percent. This means that the average emissions factor of power in the Pacific Northwest would be very clean, at 25 percent the emissions intensity of natural gas (approximately 210 lbs. CO₂ per megawatt-hour (MWh)). So at first glance, a great way to reduce a company's or a person's carbon footprint would be to move to the Pacific Northwest, where the electricity is very clean.

Yet in many cases, natural gas is the marginal resource, meaning that if a new kilowatt-hour of electricity is needed at a certain time, it will be provided by natural gas. So a company or an individual moving to the Pacific Northwest would increase carbon emissions at a rate equal to 100 percent of natural gas (840 lbs. CO₂ per MWh)—a very big difference! Thinking in marginal rather than average carbon emissions can dramatically affect a company's or a person's choice of optimal environmental impact.

Emission Factors


Average vs Marginal

If hydropower is on the margin and an energy efficiency measure reduces demand, hydropower may be scaled back. If this is accomplished by diverting water to the spillway, then the efficiency measure achieves no emissions benefits.

However, this scenario is unlikely because diverting water to the spillway is essentially throwing away free electricity. It is more likely that an energy efficiency measure would shift the use of hydro, rather than displacing it.

Under normal circumstances, if hydropower scales back in response to an energy efficiency measure, the reservoir will fill with a little extra water, which will be used to generate power at some future time, thus displacing some other generator (e.g. a gas turbine). In other words, an energy efficiency measure in hour A may shift the use of hydropower and displace the marginal unit in hour B.

Emission Factors Average vs Marginal




My friends in the Pacific Northwest may be feeling good, since, on average, 70 percent of electricity there is generated by clean hydropower and average carbon emissions are very low, but their elation is partly unwarranted.

If a new building is constructed, that adds load to the grid, or if they buy a new appliance, that increases electricity consumption, it is more likely that the additional (or marginal) electric load will be met by a coal plant in Idaho or Montana, as opposed to additional hydropower from the Grand Coulee Dam. Grand Coulee is already producing all it can, and extra (or marginal) demand must be met with generators elsewhere.

This illustrates the principal difference between average emissions and marginal emissions; when we add or subtract load from the grid, it's the marginal emissions that count.

Emission Factors Average vs Marginal



*Marginal emissions, on the other hand, represent the change in emissions that occurs when the demand for electricity is increased by a relatively small increment, say, one megawatt. Recall that the balancing authority matches supply with demand by dispatching power plants in sequence, starting with the ones having the lowest marginal cost and dispatching those having the highest marginal cost last. If an inefficient and dirty peaking power plant is on the margin, it is the one that would be shut down first if there were a reduction in electric demand, and it would be the one that would be brought on line or ramped up if demand increased. The emissions of this dirty, peaking power plant represent the marginal emissions. It's those emissions that would be avoided if we reduced consumption, and it is those emissions that would be increased if we added load. **While there are extensive hydro generating facilities in the Pacific Northwest, these plants would likely be running at capacity when electric demand is high. The marginal power plants would likely be fossil fuel plants, perhaps located in an adjacent state.***


Emission Factors

Long Run Emissions Rates

The AER's strength is its simplicity: It is derived by dividing the total emissions by the total electricity generation and adjusting for losses (Azevedo et al., 2020; eGrid, 2021). However, when used to estimate the consequences of an intervention it has a well-understood flaw in that changes to a system act on its margin, not its average. The generation mixture induced by new load often looks very different than the current average generation mixture.

Emission Factors


Average vs Marginal



Emission Factors

Average vs Marginal

Figure B-1: Hypothetical Power System Load Duration Curve and Dispatch Order



Operational Carbon Context CO₂e/kWh





Figure 7.6 | Comparative lifecycle greenhouse gas emissions from electricity supplied by commercially available technologies (fossil fuels, renewable, and nuclear power) and projected emissions of future commercial plants of currently pre-commercial technologies (advanced fossil systems with CCS and ocean energy). The figure shows distributions of lifecycle emissions (harmonization of literature values for WGIII AR5 and the full range of published values for SRREN for comparison) and typical contributions to lifecycle emissions by source (cf. the notes below). Note that percentiles were displayed for RE and traditional coal and gas in the SRREN, but not for coal CCS and gas CCS. In the latter cases, the entire range is therefore shown. For fossil technologies, fugitive emissions of methane from the fuel chain are the largest indirect contribution and hence shown separately. For hydropower, the variation in biogenic methane emissions from project to project are the main cause of the large range. See also Annex II and Annex III.

Figure 2. Life cycle greenhouse gas emission estimates for selected electricity generation and storage technologies, and some technologies integrated with carbon capture and storage (CCS).



| Estimates | 276 (+4) | 46 | 36 | 35 | 149 | 10 | 186 | 16 | 29 | 1 | 99 | 80 (+13) | 24 | 164 (+11) |
|------------|----------|----|----|----|-----|----|-----|----|----|---|----|----------|----|-----------|
| References | 57 (+2) | 17 | 10 | 15 | 22 | 5 | 69 | 4 | 3 | 1 | 27 | 47 (+11) | 10 | 53 (+9) |

Emission Factors So Many Flavors




“Some plants, like nuclear, hydro, wind and solar are generally fully utilized and will not change their generation output if you buy an EV. What changes, at least in the short run, is primarily that coal and natural gas plants will increase generation in response to this new load. So, if your question is ‘what will be the emissions consequences if I buy an EV versus a gasoline vehicle,’ which I think is the right question for policy, then the answer should use the consequential grid mix (for small changes this is the marginal generation mix) rather than the average. The marginal grid mix typically has higher emissions intensity than the average.”

However, the marginal emissions are something of a short-term estimate of EV impacts. As the demand from more EVs is added to the grid, gas and coal resources that are currently not being utilised may increase their output, but over the longer term additional generation sources will come online.”

Emission Factors So Many Flavors

'Flavors' of Carbon Emissions Rates



Compiled by Charles Eley, May 2021

Emission Factors

Long Run Emissions Rates



Long-Run Marginal CO₂e Emission Rates for End-Use
Electricity Consumption in the State of Washington

June 2021
NREL/PR-5C00-80057
Pieter Gagnon

Emission Factors

Long Run Emissions Rates

This analysis estimates the long-run marginal CO₂e emission rate for electricity Washington. The longrun marginal emission rate is an estimate of the rate of emissions that would be either induced or avoided by a long-term (i.e., more than several years) change in electrical demand (Hawkes 2014).

The long-run marginal rate explicitly takes into account both the underlying evolution of the electric grid, as well as the potential for an incremental change in electrical demand to influence the structural evolution of the grid (i.e., the building and retiring of capital assets, such as generators and transmission lines). It is therefore distinct from the more-commonly-known short-run marginal, which also identifies the marginal generator but treats the grid assets as fixed (Azevedo et al. 2020).

*The long-run marginal emission rate has been projected as typically lower than the short-run marginal emission rate, for the contiguous United States (Gagnon et al. 2020). This is because, when the potential for structural change is neglected (i.e., the short-run), the marginal generators are predominately natural gas and coal generators, **whereas when structural changes are included (i.e., the long-run) the mixture often includes a greater contribution from wind and solar generators, resulting in a lower emission rate.***

Emission Factors

Long Run Emissions Rates

“Crucially, this method captures the total effect of the change in load across the Western Interconnection – i.e., it captures the potential for policy leakage related to the Clean Energy Transformation Act (CETA).

As an example, if Washington is induced to consume more hydropower, and as a result exports less hydropower to neighboring states, it is possible that the neighboring states (not being subject to CETA) may choose to increase the utilization of their coal and natural gas generators, to make up for the reduction in hydropower. In this manner, an increase in load in Washington can result in an increase in emissions, even if the electricity being purchased by the utilities serving Washington is entirely clean. Almost all of the emitting generation sources shown in the results of this analysis are a result of this type of policy leakage.

This method produces a long-run marginal CO₂e emission rate for electricity consumed in the state of Washington. The estimate is made for an electric load introduced in 2024 and evaluated over a 20-year horizon.

The CO₂e rate reported in this analysis only includes emissions from direct combustion. It does not include upstream emissions from the fuel cycle, or the emissions associated with commissioning and decommissioning capital assets.”

Emission Factors

Long Run Emissions Rates

Why does long-run versus short-run matter?



Two reasons:

1) Long-run is less carbon-intensive than short-run

Short-run: mostly natural gas and coal

Long-run: Mostly wind, solar, natural gas, and some coal


2) Seasonal and diurnal patterns are more clear in the long-run

E.g., adding load during daylight hours is easier to serve with solar energy



Emission Factors


Forward or Long Run Emissions Factors



Embodied Carbon Solar PV

The rapid fall of solar's embodied carbon

Published on July 15, 2021



Chris Worboys

Energy & Passivhaus Consultant

+ Follow

Embodied Carbon Solar PV


Author's calculations indicate that the embodied carbon of solar in 2020 was around **615 kgCO₂/kWp**

This is **76% lower** than the **2,560 kgCO₂/kWp** that is commonly referenced.

First Solar's Global Sustainability Director also recently reported a typical value of **500-600 kgCO₂/kWp** for monocrystalline silicon.

Looking forward to 2040, Louwen et al project a drop to **325 kgCO₂/kWp** and by 2050 Pehl et al project just **205 kgCO₂/kWp**

Embodied Carbon Solar PV



Embodied Carbon Solar PV

What about the carbon payback?

Calculating a 'carbon payback' time by comparing solar's embodied carbon against operational emissions from the UK's electricity grid can suggest that long periods are required before solar achieves a carbon break-even point. There appear to be several issues with this approach that indicate it may not be a sensible way of establishing the environmental performance of solar:

1. **Technical accuracy:** It is not equitable to compare embodied emissions of solar to operational emissions for the electricity grid. This approach ignores the embodied emissions associated with fossil fuel extraction and construction of power plants, (including other sources of renewable energy). A full lifecycle emissions comparison would be fairer.
2. **Catch 22:** The carbon payback time of any renewable generator trends toward infinity as the grid decarbonises. This means if we base our decisions on carbon payback, we will never install enough renewable energy to decarbonise the electricity grid. Also note that the carbon intensity of grid electricity falls below zero in all of the National Grid's net zero compliant scenarios.
3. **Decarbonising other sectors:** Once the grid has fully decarbonised, we still need new renewable energy generation to decarbonise heating and transport, and to meet any increase in demand for electricity. If we base our decisions on carbon payback time, calculated within the power sector alone, deployment of this essential new renewable generation will never take place.
4. **Outdated figures:** Existing analyses appear to compare embodied (solar) and operational (grid) carbon emissions from two different points in time. This is producing misleading results. As the embodied carbon of solar has changed significantly over the past decade, it is important that up-to-date figures are used (though for the reasons outlined above, we might want to think about better ways to evaluate the performance of solar).

Embodied Carbon Solar PV

Moving beyond carbon payback

If we accept that carbon payback is no longer a sensible measure of solar's environmental performance, then what next?

For a start, we could acknowledge the Climate Change Committee's advice that a six fold increase in solar capacity is required; this is already reflected in the National Grid's Future Energy Scenarios.

The role of solar in achieving net zero should then become clear to architects, engineers, consultants, local authorities, and others. Hopefully this would translate into an increased sense of urgency, and the importance of good solar design would follow. This doesn't mean we should forget about embodied carbon, but focus could shift toward how to minimise it. Here are a few ideas to get started:

- Specify solar panels produced by Jinko, Longi, First Solar or Hanwha Q-Cells, who have all committed to 100% renewable electricity to supply their facilities.
- Specify high efficiency panels to reduce the amount of mounting structure required per unit of energy produced. Manufacturers are already phasing out less efficient polycrystalline technology and are increasingly competing on efficiency as a way to deliver array level cost reductions. Typical power ratings for a 1.75m x 1.05m panel are now 380W, with over 420W available, and even higher powers anticipated.
- Specify panels with a 30 year power output warranty to increase system lifetime, and select a linear power output warranty to increase lifetime system energy generation. Both reduce embodied carbon per unit of energy generated.
- Specify microinverters or DC Optimisers to increase lifetime energy yield per panel. Some microinverters have 25 year warranties, so can be expected to last two to three times as long as a central inverter on a standard warranty.
- Specify an extended warranty if using central inverters. Standard 5-12 year warranties can typically be increased to 10, 15, 20 or even 25 years for a modest additional cost.

Embodied Carbon Solar PV

Moving beyond carbon payback

- Building mounted solar is often a great way to reduce embodied carbon. In many cases, existing structure can support panels with less material than would be required for a ground mount system. Facade and roof materials can be substituted for solar panels. Roof designs can be optimised to create unshaded monopitch solar arrays, increasing energy generation, which reduces embodied carbon per unit of energy produced.
- Timber can be used in mounting systems to reduce embodied carbon, as demonstrated at one of the UK's largest solar farms:

Embodied Carbon Solar PV

Whole life carbon of photovoltaic installations TECHNICAL REPORT - FEBRUARY 2022



Embodied Carbon Solar PV

Embodied carbon results by scenarios

The following graph shows the embodied carbon impact of a whole PV installation across 25 years (assumed to be a PV service life) for different scenarios.




Figure 4 - Embodied carbon over 25 Years

Scenario 1: Project A, Flat roof, PV monocrystalline, Optimisers

Scenario 2: Project B, Pitched roof, PV monocrystalline, Optimisers

Scenario 3: Project B, Pitched roof, PV monocrystalline, No optimisers

Scenario 4: Project B, Pitched roof, PV thin-film, No optimisers

Embodied Carbon Solar PV




Figure 5: Embodied carbon of monocrystalline module over time. The size of the dot represent the market share, and the green dot represent the products used in the study.

Embodied Carbon Solar PV




Figure 6 – Embodied carbon impact associated with lifecycle stages A1-A3 from various EPDs

Embodied Carbon

Solar PV

PV as an offset mechanism - 'why it is not about payback'

We are used to thinking about the payback of measures that reduce carbon emissions – for example a financial payback (a result of energy savings) when installing additional insulation.

Recently, the industry has started looking at both the embodied carbon impact and operational carbon savings to evaluate the net effect of carbon reduction measures. This can inform decision making based on whether the embodied carbon outlay is worth the operational carbon reductions. It is tempting to take this same approach when considering whether to install PVs or not, However, doing so might have unintended consequences and could ignore other important global factors. For example, when carrying out these calculations, the future decarbonisation of the grid is taken into account based on the assumption that significantly more renewable generation will be added to the grid in coming years. In order to meet our climate targets, we need to shift progressively to 100% renewables, so new installations of PV and other renewable energy systems are required to decarbonise the grid further

This means we need to 'invest' embodied carbon into installing renewable energy infrastructure. Without that initial 'embodied carbon' investment the grid will not decarbonise further. As the grid decarbonises, local supply chains also benefit from accessing renewable energy, reducing the upfront embodied carbon content of their products.

Intuitively we can understand that PV installations are required to decarbonise our electricity grids and to move away from fossil fuels such as coal and gas. The UK grid needs to substantially increase capacity to deal with the likely increased demand of the energy in the future (e.g. heat pumps and electric cars) and rooftop solar PV represents a significant opportunity to support this renewable energy generation push.

Even though our results suggest that PV as a pure carbon offset mechanism will be less useful going forward (as operational offsets diminish in line with decarbonisation), the additional renewable capacity to help balance supply and demand will be far more important in its contribution to the energy transition.

Embodied Carbon Battery Storage



No. C 444
November 2019

Lithium-Ion Vehicle Battery Production

Status 2019 on Energy Use, CO₂ Emissions,
Use of Metals, Products Environmental
Footprint, and Recycling

Erik Emilsson, Lisbeth Dahlöf




In cooperation with the Swedish Energy Agency

According to new calculations, the production of lithium-ion batteries on average emits somewhere between 61-106 kilos of carbon dioxide equivalents per kilowatt-hour battery capacity produced. If less transparent data is included, the upper value will be higher; 146 kilos carbon dioxide equivalents per kilowatt hour produced. The large emissions range primarily depends on production methods and the type of electricity used in the battery manufacturing process. Current figures for climate emissions are lower than they were in the 2017 report where the average was 150-200 kilos of carbon dioxide equivalents per kWh of battery capacity.

"That emissions are lower now is mainly due to the fact that battery factories have been scaled up and are running at full capacity, which makes them more efficient per unit produced. We have also taken into account the possibility of using electricity that is virtually fossil-free in several of the production stages," says Erik Emilsson

Embodied Carbon Battery Storage

Solid state batteries can reduce carbon footprint of EV batteries even further



Results for displayed solid state batteries are with an oxide solid electrolyte and a NMC cathode
Source: Minviro (2022), Comparative Life Cycle Assessment Study Of Solid State And Lithium-Ion Batteries For Electric Vehicle Application In Europe

Embodied Carbon Heat Pumps

CIBSE
JOURNAL



Sponsor of Heating content on [CIBSEJournal.com](https://www.cibsejournal.com)

Embodied energy: the whole picture

New CIBSE research shows that embodied energy in heating and hot-water systems accounts for up to 25% of a dwelling's whole-life embodied carbon. Elementa Consulting's Yara Machnoug reports on the study that will form the basis of CIBSE guidance TM65.1


Posted in October 2021



UK heat and hot-water systems examined contain an average of 9kgCO₂e per kg of product weight

Embodied Carbon Heat Pumps


All products' kgCO₂e/kg (A1–A4, B3, C2–C4) without refrigerant



Embodied Carbon Heat Pumps

The range of embodied carbon impact (at product level) by weight of products investigated is estimated between **3kgCO₂e/kg** and **21kgCO₂e/kg**, and the average is **9kgCO₂e/kg** (excluding refrigerant).

Embodied Carbon Heat Pumps



The dotted line indicates the average generic embodied carbon value.

Figure 2: Embodied carbon emissions for different sizes of ASHPs

Embodied Carbon E3 Calculator & MEP 2040

Refrigerant Impact Calculator **MEP 2040**
Powered by BHoM

ABOUT 

Input

EQUIPMENT LIFE EXPECTANCY Dataset ▾

REFRIGERANT Dataset ▾

REFRIGERANT CHARGE (KG) 100 Kg

LEAKAGE RATE Dataset ▾

Sources

| Leakage rate datasets | | | | | |
|---|--------------|--------|----------------------|--------------------------|--|
| Dataset | Installation | Annual | End of life recovery | Remaining at end of life | Additional notes |
| ASHRAE 228P Refrigerant Leakage Rates | | ✓ | | | |
| BREEAM Refrigerant Leakage Rates | | ✓ | | | |
| CIBSE TM65 2021 Refrigerant Leakage Scenarios | | ✓ | ✓ | | |
| EPA Refrigerant Leakage Rates | ✓ | ✓ | ✓ | ✓ | |
| GHG Protocol Leakage Rates | ✓ | ✓ | ✓ | | High and Low Values provided for Installation, Annual and End of Life Recovery |

| Life Expectancy datasets | | |
|---|-----------------|-----------------------------------|
| Dataset | Life expectancy | Additional notes |
| GHG Protocol Leakage Rates | ✓ | Median Value Extracted from Table |
| LEED Default Equipment Life | ✓ | |

Embodied Carbon E3 Refrigerant Avoided Cost Calculator



Energy+Environmental Economics

3. Refrigerant leakage for device *i*

This use case was developed primarily to calculate the increases in GHG impact due to refrigerant leakage when new heat pump devices are installed. This calculation can also determine changes in GHG impact when high GWP refrigerants are replaced with lower GWP refrigerants, or when a new device replaces an older one with a different refrigerant charge, leakage rate, or refrigerant.

The cost of refrigerant leakage will be determined by multiplying the refrigerant leakage by the natural gas GHG value. This allows us to estimate either increased or decreased GHG costs for any situation where refrigerant charge (M_i), leakage ($q_{ann,i} t_i + q_{EOL,i} (1 - q_{ann,i} t_{EOL,i})$), or refrigerant GWP (GWP_i) has changed. Note that the natural gas GHG value is used instead of the electric model GHG adder because [this use case applies primarily to building electrification measures](#).

The term ($q_{ann,i} t_i + q_{EOL,i} (1 - q_{ann,i} t_{EOL,i})$) represents the fraction of refrigerant charge that is leaked into the atmosphere over the device's life. It includes both the operational leakage that occurs through normal use, and the end-of-life leakage that occurs at disposal. The operational leakage is equal to the annual leakage rate (q_{ann}) multiplied by the device's expected useful lifetime (t). The end-of-life leakage depends on both the end-of-life leakage rate for each device (q_{EOL}), which depends on the typical disposal practice for device type (i) and on the extent to which refrigerant that is lost during the device's lifetime is replaced (i.e., "topped off").

For example, disposal practices for residential heat pump devices often do not follow regulations requiring refrigerant recycling, and instead the refrigerant is generally vented (i.e., completely leaked) before disposal. If this occurs in 85% of the units disposed, then, $q_{EOL,i} = 85\%$ for these types of devices. If the device is never topped off (as is typical for some residential devices) then $t_{EOL} = t - 20$ years. If the annual leakage rate (q_{ann}) is 2%/year and the effective useful life (t) is 20 years, then the total leakage is

$$\begin{aligned} & q_{ann,i} t_i + q_{EOL,i} (1 - q_{ann,i} t_{EOL,i}) \\ &= 2\%/year * 20 \text{ years} + 85\% [1 - (2\%/year * 20 \text{ years})] \\ &= 40\% + 85\% (1 - 40\%) \\ &= 40\% + 51\% \\ &= 91\% \end{aligned}$$


Value of refrigerant leakage =

$$- M_i * (q_{ann,i} t_i + q_{EOL,i} (1 - q_{ann,i} t_{EOL,i})) * GWP_i * P_{CHG}$$

(tonnes) (dimensionless) $\left(\frac{\text{tonnes CO}_2e}{\text{tonne}}\right)$ $\left(\frac{\$}{\text{tonne CO}_2e}\right)$

The 2022 Refrigerant Calculator was updated such that refrigerant leakage is discounted at the mid-year rather than the end-of-year to be more consistent with continual leakage throughout a device's life. Note that in some cases, a measure may lead to an incurred cost due to refrigerant leakage rather than avoided cost. For instance, if a heat pump replaced a counterfactual natural gas appliance, the natural gas appliance

Embodied Carbon Heat Pumps



Background: Progress towards the HFC phase-down targets under the Kigali Amendment will be measured in **tonnes CO₂ equivalent**. It is very important that policy makers and industry stakeholders understand how this parameter is calculated and the way that it enables a flexible approach to HFC phase-down to be adopted by each country. To calculate tonnes CO₂ equivalent it is necessary to know the **GWP¹** (global warming potential) of each relevant gas.

What is GWP? Global warming potential (GWP) is a measure of the relative global warming effects of different gases. The GWP indicates the amount of heat trapped by 1 tonne of a gas relative to the amount of heat trapped by 1 tonne of CO₂ over a specific period. CO₂ was chosen by the Intergovernmental Panel on Climate Change (IPCC) as the reference gas and its GWP is defined as 1. Most HCFCs and HFCs have GWPs that are thousands of times higher than the GWP of CO₂. For example, HFC-134a has a GWP of 1 430. This means that the emission of 1 tonne of HFC-134a will create the same contribution to global warming as the emission of 1 430 tonnes of CO₂.

Why are there different GWP values for the same gas? Different publications do not always quote the same GWP values for a particular gas. There are two main reasons for this:

- GWPs can be defined to measure impact over different timescales, e.g. 20 years, 100 years or 500 years. This results in different GWP values for each of these timescales.
- There is some uncertainty about the best GWP value to assign to each gas. A key source of GWP data are the IPCC Assessment Reports. GWP values published by the IPCC have been updated several times over the last 20 years.

GWPs used under the Kigali Amendment: Under the Kigali Amendment a standard set of GWP values has been agreed for reporting consumption and production of HFCs. The GWPs of HCFCs and HFCs are listed in Annex C and Annex F of the Montreal Protocol and are based on the 100-year GWPs in the IPCC 4th Assessment Report.

Some HCFCs and HFCs are used as pure fluids e.g. HFC-134a in various RAC applications. However, many of the most commonly used HFCs are blends of two or more separate HFC molecules. The GWP of a blend is the weighted average of the GWPs of the blend components. See Box 1 for an example calculation of a blend GWP.

Box 1: Calculating the GWP of a Blend

A widely-used blend is R-404A. It consists of:

52% HFC-143a + 44% HFC-125 + 4% HFC-134a

GWPs: HFC-143a: 4470 HFC-125: 3500 HFC-134a: 1430

Blend GWP = 52% * 4470 + 44% * 3500 + 4% * 1430

= 3922

| Group | Fluid | Montreal Protocol Standard GWP Value |
|------------|-----------|--------------------------------------|
| HFCs | HFC-134a | 1 430 |
| | HFC-227ea | 3 220 |
| HFC blends | R-404A | 3 922 |
| | R-410A | 2 088 |
| HCFCs | HCFC-22 | 1 810 |
| | HCFC-141b | 725 |

The GWPs of HCFCs are of importance because they form part of a country's baseline consumption (see [Kigali Fact Sheet 5](#) for details on baselines).

The table shows the GWP values that should be used for some of the most common HFCs and HCFCs. A table at the end of this Fact Sheet includes a comprehensive list of GWP values for all relevant molecules and blends.

¹ See [Kigali Fact Sheet 14](#) for a glossary of all acronyms used

Embodied Carbon Heat Pumps

What is GWP?

Global warming potential (GWP) is a measure of the relative global warming effects of different gases. The GWP indicates the amount of heat trapped by 1 ton of a gas relative to the amount of heat trapped by 1 ton of CO₂ over a specific period.

CO₂ was chosen by the Intergovernmental Panel on Climate Change (IPCC) as the reference gas and its GWP is defined as 1.

Embodied Carbon Heat Pumps

GWP20 vs GWP100

Different publications do not always quote the same GWP values for a particular gas. There are two main reasons for this:

- a) GWPs can be defined to measure impact over different timescales, e.g. 20 years, 100 years or 500 years. This results in different GWP values for each of these timescales.
- b) There is some uncertainty about the best GWP value to assign to each gas. A key source of GWP data are the IPCC Assessment Reports. GWP values published by the IPCC have been updated several times over the last 20 years.

The large contribution of projected HFC emissions to future climate forcing



Guus J. M. Velders^{a,1}, David W. Fahey^b, John S. Daniel^b, Mack McFarland^c, and Stephen O. Andersen^d

^aNetherlands Environmental Assessment Agency, PO Box 303, 3720 AH Bilthoven, The Netherlands; ^bNational Oceanic and Atmospheric Administration, Earth System Research Laboratory, Boulder, CO 80305; ^cDuPont Fluoroproducts, Wilmington, DE 19805; and ^dU.S. Environmental Protection Agency, Code 6202J, 1200 Pennsylvania Avenue NW, Washington, DC 20460

Edited by Mark H. Thiemens, University of California at San Diego, La Jolla, CA, and approved May 14, 2009 (received for review March 13, 2009)

The consumption and emissions of hydrofluorocarbons (HFCs) are projected to increase substantially in the coming decades in response to regulation of ozone depleting gases under the Montreal Protocol. The projected increases result primarily from sustained growth in demand for refrigeration, air-conditioning (AC) and insulating foam products in developing countries assuming no new regulation of HFC consumption or emissions. New HFC scenarios are presented based on current hydrochlorofluorocarbon (HCFC) consumption in leading applications, patterns of replacements of HCFCs by HFCs in developed countries, and gross domestic product (GDP) growth. Global HFC emissions significantly exceed previous estimates after 2025 with developing country emissions as much as 800% greater than in developed countries in 2050. Global HFC emissions in 2050 are equivalent to 9–19% (CO₂-eq. basis) of projected global CO₂ emissions in business-as-usual scenarios and contribute a radiative forcing equivalent to that from 6–13 years of CO₂ emissions near 2050. This percentage increases to 28–45% compared with projected CO₂ emissions in a 450-ppm CO₂ stabilization scenario. In a hypothetical scenario based on a global cap followed by 4% annual reductions in consumption, HFC radiative forcing is shown to peak and begin to decline before 2050.

preferred refrigerant in consumer products requiring a large charge, where hydrocarbon flammability is problematic (6). The use of HFCs is expected to be minor in many other applications because other low-GWP compounds and not-in-kind (i.e., non-halocarbon based) technologies are available. Overall, not-in-kind technologies are not expected to initially satisfy as large a fraction of future demand as was the case during the CFC phaseout (7).

Multiple scenarios of global HFC emissions are available from SRES (8) and IPCC/TEAP (2). These scenarios are now of limited use because of limited range of years (IPCC/TEAP) or outdated assumptions concerning the transition from HCFCs to HFCs (SRES). The SRES GWP-weighted emissions for refrigeration and AC are ≈20% below what we infer here from observed atmospheric mixing ratios for 2007 (*SI Text*). The 2007 HFC emissions for these applications from IPCC/TEAP (2) are somewhat higher, but this scenario ends in 2015. Others (9–11) have reported HFC scenarios similar to the SRES assumptions and do not consider a more detailed market development as discussed here.

We report new baseline scenarios for the consumption and

Embodied Carbon Heat Pumps

Table S2. Major applications, lifetimes, direct global warming potentials and radiative efficiencies of the major HCFCs and HFCs

| Compound | Main applications | Lifetime, years | GWP, 20-year | GWP, 100-year | GWP, 500-year | Radiative efficiency (W·m ⁻² ·ppb ⁻¹) |
|--|--|-----------------|--------------|---------------|---------------|--|
| HCFC-22 | Refrigeration, AC | 12 | 5,160 | 1,810 | 549 | 0.2 |
| HCFC-141b | Insulating foams | 9.3 | 2,250 | 725 | 220 | 0.14 |
| HCFC-142b | Insulating foams | 17.9 | 5,490 | 2,310 | 705 | 0.2 |
| HFC-32 | Refrigeration, AC | 4.9 | 2,330 | 675 | 205 | 0.11 |
| HFC-125 | Refrigeration, AC | 29 | 6,350 | 3,500 | 1,100 | 0.23 |
| HFC-134a | Refrigeration, AC, Mobile AC, Insulating foams | 14 | 3,830 | 1,430 | 435 | 0.16 |
| HFC-143a | Refrigeration, AC | 52 | 5,890 | 4,470 | 1,590 | 0.13 |
| HFC-152a | Plastic foams, Aerosols | 1.4 | 437 | 124 | 38 | 0.09 |
| HFC-245fa | Insulating foams | 7.6 | 3,380 | 1,030 | 314 | 0.28 |
| HFC-365mfc | Insulating foams | 8.6 | 2,520 | 794 | 241 | 0.21 |
| R-404A* | Refrigeration, AC | | 6,010 | 3,922 | 1,328 | |
| R-410A† | Refrigeration, AC | | 4,340 | 2,088 | 653 | |
| Average values weighted by consumption in developing countries | | | | | | |
| HCFCs | | 11.4 | 4,299 | 1,502 | 456 | |
| HFCs | | 21.7‡ | 4,582‡ | 2,362‡ | 766‡ | |


Values taken from IPCC (26).

*R-404A is a blend of HFC-143a (52%), HFC-125 (44%), and HFC-134a (4%).

†R-410A is a blend of HFC-32 (50%) and HFC-125 (50%).

‡Values corresponding to the year 2040.

Embodied Carbon Heat Pumps



REFRIGERANT METRIC: REFRIGERANT LBS / COOLING TON

The following emissions charts were sourced from previous PAE mechanical system designs based on the building and system type. The table below details an estimated refrigerant volume (lb) per ton of cooling. These metrics are organized by building type and mechanical system. Notice that distributed refrigerant systems such as VRF have high coefficients. High performance buildings should aim to have low refrigerant charges.




Figure 15: Refrigerant Pounds/Cooling Ton - Multifamily




Figure 16: Refrigerant Pounds/Cooling Ton - Multifamily

City of Seattle Refrigerant Emissions Analysis


GHG Emissions Calculation Methodologies

May 5, 2020

pae-engineers.com

Embodied Carbon Heat Pumps

Refrigerants & Environmental Impacts A BEST PRACTICE GUIDE



Embodied Carbon Heat Pumps

Leakage Rates

Based on published data the following assumptions concerning annual refrigerant leakage could be assumed as follows:

| Product | Annual leak rate - low | Annual leak rate - medium | Annual leak rate - high |
|--|------------------------|---------------------------|-------------------------|
| Centralised and individual systems – where no refrigerant is initially charged on-site | 1% | 3.8% | 6% |
| Distributed systems where a large amount of refrigerant pipework is installed and filled on-site | 1% | 6% | 10% |

Embodied Carbon Heat Pumps

Leakage Rates

The following table lists annual leakage rates reported from various studies:

| Reference | Type of plant | Annual leak rate | date of paper | |
|--|--|----------------------|---------------|-----|
| TM56 - Resource efficiency of building services | Air-cooled chiller | Lower | 1% | |
| | | Upper | 5% | |
| | Water-cooled chiller | Lower | 1% | |
| | | Upper | 5% | |
| | Rooftop | Lower | 1% | |
| | | Upper | 5% | |
| | Split system | Lower | 2% | |
| | | Upper | 8% | |
| | VRF system | Lower | 1% | |
| | | Upper | 10% | |
| | Methods of calculating Total Equivalent Warming Impact | Chillers | Lower | 5% |
| | | | Typical | 7% |
| Upper | | | 9% | |
| Roof top packaged systems | | Lower | 4% | |
| | | Typical | 5% | |
| | | Upper | 9% | |
| Split systems (single and multi) | | Lower | 3% | |
| | | Typical | 4% | |
| | | Upper | 9% | |
| BREEAM 2018 | | Unitary split | Typical | 15% |
| | Small scale chillers | Typical | 10% | |
| | Heat pumps | Typical | 6% | |
| Impacts of Leakage from Refrigerants in Heat Pumps | Heat pumps | Lower | n/a | |
| | | Typical non-domestic | 3.80% | |
| | | Typical domestic | 3.5% | |
| | | Upper | n/a | |

APPENDICES | A4 REFRIGERANT LEAKAGE

continued overleaf

Embodied Carbon Heat Pumps

Leakage Rates

| Reference | Type of plant | Annual leak rate | date of paper | |
|--|--|-----------------------|---------------|-------|
| Cold Hard Facts 3 | Small AC sealed- | Theoretical leak rate | 2.5% | 2016 |
| | HW heat pump: domestic- | Service rate | 2% | |
| | Small AC: Split: | Theoretical leak rate | 3.5% | |
| | Single split: non-ducted | Service rate | 2% | |
| | Medium AC | Theoretical leak rate | 2.7% | |
| | Split system: ducted | Service rate | 2% | |
| | VRV/VRF split system | Service rate | 2% | |
| | Multi split | Service rate | 2% | |
| | Large AC | Theoretical leak rate | 4.5% | |
| | Large AC <350 kWr | Service rate | 4% | |
| March (1991) as cited in BNCR36: Direct Emission of Refrigerant Gases | Heat pumps | Lower | 3% | 1991 |
| | | Upper | 10% | |
| Haydock et al (2003) as cited in BNCR36: Direct Emission of Refrigerant Gases | Heat pumps | Lower | 3% | 2003 |
| | | Upper | 5% | |
| ETSU (1997) as cited in BNCR36: Direct Emission of Refrigerant Gases | Heat pumps | Typical | 4% | 2007 |
| Evaluation of the leakage rates of 11,000 refrigeration systems in Hungary (34) cited by Schwarz | Stationary refrigeration and air conditioning equipment >3 kg. | Average | 10% | 2010 |
| 2013 Annual Conference of the Institute of Refrigeration LEC Leakage & Energy Control System by VDFK | 74,000 refrigerant units in different applications | Average | 3.16% | 2013 |
| International Institute of Refrigeration | Commercial chillers | Upper | 15% | <2017 |
| | Residential & light systems | Upper | 10% | |

Hamot, L., Dugdale, H., & Boennec, O. (2020, September 1). Refrigerants & Environmental Impacts: A Best Practice Guide. Integral Group. <https://www.integralgroup.com/news/refrigerants-environmental-impacts/>

Embodied Carbon Heat Pumps



Impact of Refrigerants: Fact Sheet #1 (V.1.1.)

Real GWP: 20 years vs.100 years

| Refrigerant | Type | Composition | GWP 100 years | "Real" GWP 20 years |
|-------------------------|-------------|---|------------------|------------------------|
| R404A | HFC | 44% R125 / 4% R134a / 52% R143a | 4,200 | 6,600 |
| R22 | HCFC | 100% R22 | 1,780 | 5,310 |
| R407A | HFC | 20% R32 / 40% R125 / 50% R134a | 2,100 | 4,500 |
| R410A | HFC | 50% R125 / 50% R32 | 2,100 | 4,400 |
| R407C | HFC | 23% R32 / 25% R125 / 52% R134a | 1,700 | 4,100 |
| R134a | HFC | 100% R134a | 1,360 | 3,810 |
| R448A (Solstice N40) | HFC/ HFO | 26% R32 / 26% R125 / 21% R134a / 7% R1234ze / 20% R1234yf | 1,400 | 3,100 |
| R449A (Opteon XP40) | HFC/ HFO | 24,3% R32 / 24,7% R125 / 25,7% R134a / 25,3% R1234yf | 1,400 | 3,100 |
| R449C (Opteon XP20) | HFC/ HFO | 20% R32 / 20% R125 / 29% R134a / 31% R1234yf | 1,200 | 2,900 |
| R32 | HFC | 100% R32 | 704 | 2,530 |
| R452B (Opteon XL55) | HFC/ HFO | 67% R32 / 7% R125 / 26% R1234yf | 710 | 2,100 |
| R513A (Opteon XP10) | HFC/ HFO | 44% R134a / 56% R1234yf | 600 | 1,700 |
| R454B | HFC/ HFO | 68.9% R32 / 31.1% R1234yf | 490 | 1,700 |
| R450A (Solstice N13) | HFC/ HFO | 42% R134a / 58% R1234ze | 570 | 1,600 |
| R744 | Natural | CO ₂ | 1 | 1 |
| R600a | Natural | Isobutane | <1 | <1 |
| R290 | Natural | Propane | <1 | <1 |
| R1270 | Natural | Propylene | <1 | <1 |
| R717 | Natural | NH ₃ | 0 | 0 |
| R718 | Natural | H ₂ O | 0 | 0 |
| R729 | Natural | Air | 0 | 0 |

Table 1: The "real" impact of refrigerants on the environment over the next 20 years. Source: UNEP¹

Embodied Carbon Heat Pumps



Model Search:

[HOME](#) | [NOMENCLATURE](#) | [ACCESSORIES](#) | [CONTROLS](#) | [M-SERIES](#) | [P-SERIES](#) | [SMART MULTI](#) |
[S-SERIES](#) | [Y-SERIES \(VRF HEAT PUMP\)](#) | [R2-SERIES \(VRF HEAT RECOVERY\)](#) | [VENTILATION](#) | [JET TOWEL](#) |
[SOFTWARE](#) | [SUPPORT](#) | [POLICIES](#) | [APP NOTES](#) | [TECH TIPS](#) | [CATALOGS](#) |

[Home](#)

LinkDrive

Welcome to LinkDrive 4.0

Can't find or believe LinkDrive is missing a needed document? Let us know at LinkDrive@hvac.me.com



Embodied Carbon Heat Pumps

P-Series R410A Outdoor Units



H2i Hyper-heating Heat Pump

Slim and compact, INVERTER-driven compressor, quiet, Pulse Amplitude Modulation (PAM), Pulse Wave Modulations (PWM): Vector Wave Eco INVERTER, low ambient cooling operation down to 0 deg F (with wind baffle), A-control connection. Same indoor units used with both cooling-only and heat pump outdoor models, auto cool/heat changeover.

Production: 2021 - Current

- PUZ-HA24NHA1
- PUZ-HA30NKA
- PUZ-HA36NKA
- PUZ-HA42NKA1

M-Series R410A Outdoor





SUZ Single-zone Hyper-heating Universal Heat Pump

Single-zone, H2i hyper-heating heat pump Universal Outdoor unit. Pairs with M-Series ceiling cassettes, horizontal-ducted or air handler. Blue Fin anti-corrosion treatment on heat exchanger. Most models Energy Star certified. SEER up to 20.3

Production: 2020 - Current

- SUZ-KA09NAHZ.TH
- SUZ-KA12NAHZ.TH
- SUZ-KA15NAHZ.TH
- SUZ-KA18NAHZ.TH
- SUZ-KA24NAHZ
- SUZ-KA30NAHZ
- SUZ-KA36NAHZ

Embodied Carbon Heat Pumps

| M-SERIES SUBMITTAL DATA: SEZ-KD09NA4 & SUZ-KA09NAHZ 9,000 BTU/H HORIZONTAL-DUCTED HEAT PUMP SYSTEMS | | MITSUBISHI ELECTRIC |
|---|---|------------------------|
| Job Name: | | |
| System Reference: | | Date: |
| APPLIES TO INDOOR UNIT: <input type="checkbox"/> SEZ-KD09NA4.TH <input type="checkbox"/> SEZ-KD09NAR1.TH <input type="checkbox"/> SEZ-KD09NA4R1.TH | Outdoor Unit: SUZ-KA09NAHZ | |
|  |  | |

INDOOR UNIT FEATURES

- Concealed horizontal-ducted unit for applications with short duct runs
- Quiet operation
- Ultra-thin body: 7-7/8" high
- Built-in condensate lift mechanism (lifts to 21-21/32")
- Multiple control options available:
 - kumo cloud® smart device app for remote access
 - Third-party interface options
 - Wired or wireless controllers
- Static capability up to 0.20 in. WG

OUTDOOR UNIT FEATURES

- The outdoor unit powers the indoor unit, and should a power outage occur, the system is automatically restarted when power returns
- INVERTER-driven compressor and LEV provide high efficiency and comfort while using only the energy needed to maintain maximum performance
- H2® hyper heat performance offers 100% heating capacity at 5°F
- Hot-Start Technology: no cold air rush at equipment startup or when restarting after Defrost Cycle
- Quiet operation
- Blue Fin anti-corrosion treatment applied to the outdoor unit heat exchanger for increased coil protection and longer life
- Built-in base pan heater
- Innovative Joint Lap DC Motor leads to high efficiency and reliability
- Pulse Amplitude Modulation technology

Embodied Carbon Heat Pumps

SPECIFICATIONS: SEZ-KD09NA4 & SUZ-KA09NAHZ


| | | | | |
|--|--|-------------|--------------------------------|---------------|
| | | D: in. (mm) | 35-7/16 (900) | |
| | | H: in. (mm) | 14-3/16 (360) | |
| | Unit Weight | Lbs. (kg) | 42 (19) | |
| | Package Weight | Lbs. (kg) | 64 (29) | |
| Indoor Unit Operating Temperature Range | Cooling Intake Air Temp (Maximum / Minimum)* | *F | 90 DB / 72 WB // 68 DB / 61 WB | |
| | Heating Intake Air Temp (Maximum / Minimum) | *F | 77 DB // 59 DB | |
| Outdoor Unit | MCA | A | 14.0 | |
| | MOCP | A | 24.0 | |
| | Fan Motor Full Load Amperage | A | 0.7 | |
| | Fan Motor Output | W | 77.0 | |
| | Airflow Rate | CFM | 1,691 / 1,691 | |
| | Refrigerant Control | | LEV | |
| | Defrost Method | | Reverse Cycle | |
| | Heat Exchanger Type | | Plate Fin Coil | |
| | Blue Fin Coating on Heat Exchanger | | Yes | |
| | Sound Pressure Level (Cooling) ¹ | dB(A) | 54 | |
| | Sound Pressure Level, Heating ² | dB(A) | 55 | |
| | Compressor Type | | DC INVERTER-driven Twin Rotary | |
| | Compressor Model | | SNB130FHB2T | |
| | Compressor Rated Load Amps | A | 13 | |
| | Compressor Locked Rotor Amps | A | 10 | |
| | Compressor Oil Type // Charge | oz. | FV50S // 22 | |
| | External Finish Color | | Ivory Munsell 3Y 7.8/1.1 | |
| | Base Pan Heater | | Yes | |
| | Unit Dimensions | W: in. (mm) | | 38-9/16 (840) |
| | | D: in. (mm) | | 13 (330) |
| H: in. (mm) | | | 34-5/8 (880) | |
| Package Dimensions | W: in. (mm) | | 38-9/16 (980) | |
| | D: in. (mm) | | 16-9/16 (420) | |
| | H: in. (mm) | | 39 (990) | |
| Unit Weight | Lbs. (kg) | | 129 (58.5) | |
| Package Weight | Lbs. (kg) | | 148 (67) | |
| Outdoor Unit Operating Temperature Range | Cooling Air Temp (Maximum / Minimum)* | *F | 115 / 14 | |
| | Cooling Thermal Lock-out / Re-start Temperatures** | *F | -1 / 3 | |
| | Heating Air Temp (Maximum / Minimum) | *F | 75 / -13 | |
| | Heating Thermal Lock-out / Re-start Temperatures** | *F | -18 / -14 | |
| Refrigerant | Type | | R410A | |
| | Charge | Lbs, oz | 3, 9 | |

Embodied Carbon Heat Pumps

SPECIFICATIONS: SEZ-KD09NA4 & SUZ-KA09NAHZ

| | | | | |
|--|--|-------------|--------------------------------|---------------|
| | | D: in. (mm) | 35-7/16 (900) | |
| | | H: in. (mm) | 14-3/16 (360) | |
| | Unit Weight | Lbs. (kg) | 42 (19) | |
| | Package Weight | Lbs. (kg) | 64 (29) | |
| Indoor Unit Operating Temperature Range | Cooling Intake Air Temp (Maximum / Minimum)* | *F | 90 DB / 72 WB // 68 DB / 61 WB | |
| | Heating Intake Air Temp (Maximum / Minimum) | *F | 77 DB // 59 DB | |
| Outdoor Unit | MCA | A | 14.0 | |
| | MOCP | A | 24.0 | |
| | Fan Motor Full Load Amperage | A | 0.7 | |
| | Fan Motor Output | W | 77.0 | |
| | Airflow Rate | CFM | 1,691 / 1,691 | |
| | Refrigerant Control | | LEV | |
| | Defrost Method | | Reverse Cycle | |
| | Heat Exchanger Type | | Plate Fin Coil | |
| | Blue Fin Coating on Heat Exchanger | | Yes | |
| | Sound Pressure Level (Cooling) ¹ | dB(A) | 54 | |
| | Sound Pressure Level, Heating ² | dB(A) | 55 | |
| | Compressor Type | | DC INVERTER-driven Twin Rotary | |
| | Compressor Model | | SNB130FHB2T | |
| | Compressor Rated Load Amps | A | 13 | |
| | Compressor Locked Rotor Amps | A | 10 | |
| | Compressor Oil Type // Charge | oz. | FV50S // 22 | |
| | External Finish Color | | Ivory Munsell 3Y 7.8/1.1 | |
| | Base Pan Heater | | Yes | |
| | Unit Dimensions | W: in. (mm) | | 38-9/16 (840) |
| | | D: in. (mm) | | 13 (330) |
| H: in. (mm) | | | 34-5/8 (880) | |
| Package Dimensions | W: in. (mm) | | 38-9/16 (980) | |
| | D: in. (mm) | | 16-9/16 (420) | |
| | H: in. (mm) | | 39 (990) | |
| Unit Weight | Lbs. (kg) | | 129 (58.5) | |
| Package Weight | Lbs. (kg) | | 148 (67) | |
| Outdoor Unit Operating Temperature Range | Cooling Air Temp (Maximum / Minimum)* | *F | 115 / 14 | |
| | Cooling Thermal Lock-out / Re-start Temperatures** | *F | -1 / 3 | |
| | Heating Air Temp (Maximum / Minimum) | *F | 75 / -13 | |
| | Heating Thermal Lock-out / Re-start Temperatures** | *F | -18 / -14 | |
| Refrigerant | Type | | R410A | |
| | Charge | Lbs, oz | 3, 9 | |

Basic level calculation:



Embodied Carbon Ventilation


Ventilation TM65 Calculation



VL-250CZPVU-R/L-E

CIBSE TM65 Embodied Carbon Mid-level Calculation

| | |
|---|--|
| Assessment Date: 22nd June 2021 | Embodied Carbon Result with 'Mid-level TM65 Calculation' Method Total: 304 (kg CO₂e) |
| Assessor / Organisation: Mitsubishi Electric | |
| Contact: embodied.carbon@meuk.mee.com | |



VL-250CZPVU-R/L-E - Product Information

| | |
|--|------------------|
| Type of product | MVHR |
| Capacity of equipment (kW) | N/A |
| Product weight (kg) | 26 |
| Material breakdown for at least 95% of the product weight? (Y/N) | Y |
| Service life of the product (years) | 15 |
| Type of refrigerant | N/A |
| Refrigerant GWP | N/A |
| Energy consumption of the factory per unit of product (kWh) | 5.15 |
| Location of manufacture | Japan |
| Product Complexity | Category 3: High |



ies.mitsubishielectric.co.uk

304 kgCO₂e

26 kg

=

11.7 kgCO₂e/kg

Embodied Carbon Ventilation

Ventilation **TM65 Calculation**



VL-250CZPVU-R/L-E

CIBSE TM65 Embodied Carbon Mid-level Calculation

| Embodied Carbon Results Breakdown (kg CO ₂ e) | |
|---|-----------------------------------|
| A1: Material extraction | 174 |
| A2: Transport | 21 |
| A3: Manufacturing | 9 |
| A4: Transport to Site | 7 |
| B1: Use | - |
| B3: Repair | 21 |
| C1: Deconstruction | - |
| C2: Transport | 0.3 |
| C3: Waste Processing | 1 |
| C4: Disposal | 0.1 |
| Embodied Carbon Results - without Refrigerant Leakage (kg CO₂e) | |
| A1-C4 (excluding B1,C1) | 234 |
| A1-C4 with Buffer Factor (excluding B1, C1) | 304 |
| Embodied Carbon Result - Refrigerant Leakage Only (kg CO₂e) | |
| B1 (Refrigerant leakage during use) + C1 (Refrigerant leakage end of life) | - |
| Assumptions | |
| A1: Material carbon coefficient source | TM65 Table 2.1 & The ICE Database |
| B1: Refrigerant annual leakage rate (%) | N/A |
| C1: Refrigerant end of life recovery rate (%) | N/A |
| B3: Materials replaced as part of repair (%) | 10 (TM65 Assumption) |
| C4: Percentage of product going to landfill (%) | 60 (TM65 Assumption) |



Telephone: 01707 282880
 email: embodied.carbon@meukmee.com
 les.mitsubishielectric.co.uk



UNITED KINGDOM Mitsubishi Electric Europe Living Environment Systems Division, Travellers Lane, Hatfield, Hertfordshire, AL10 8XB, England. Telephone: 01707 282880 Fax: 01707 278881
 IRELAND Mitsubishi Electric Europe, Westgate Business Park, Ballymount, Dublin 24, Ireland. Telephone: (01) 419 8800 Fax: (01) 419 8890 International code: (003531)

Country of origin: United Kingdom - Japan - Thailand - Malaysia. ©Mitsubishi Electric Europe 2021. Mitsubishi and Mitsubishi Electric are trademarks of Mitsubishi Electric Europe BV. The company reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement. Mitsubishi Electric is constantly developing and improving its products. All descriptions, illustrations, drawings and specifications in this publication present only general particulars and shall not form part of any contract. All goods are supplied subject to the Company's General Conditions of Sale, a copy of which is available on request. Third party product and brand names may be trademarks or registered trademarks of their respective owners.

Note: The fuse rating is for guidance only. Please refer to the relevant databook for detailed specification. It is the responsibility of a qualified electrical engineer to select the correct cable size and fuse rating based on current regulation and site specific conditions. Mitsubishi Electric air conditioning equipment and heat pump systems contain fluorinated greenhouse gas. R410A (GWP 2088), R32 (GWP 675), R450C (GWP 176), R32a (GWP 1428), R410A (GWP 1975), R450B (GWP 468), R132a (GWP 2) or R132aF (GWP 4). These GWP values are based on Regulation (EU) No 517/2014 from IPCC 4th edition. In case of Regulation (EU) No 528/2011 from IPCC 3rd edition, these are as follows: R410A (GWP 1975), R32 (GWP 152), R450C (GWP 182) or R132a (GWP 102).

Effective as of July 2021



Embodied Carbon Ventilation


Ventilation **TM65 Calculation**



LGH-100RVX-E

CIBSE TM65 Embodied Carbon Mid-level Calculation

| | | |
|--------------------------|------------------------------|--|
| Assessment Date: | 22nd June 2021 | Embodied Carbon Result with 'Mid-level TM65 Calculation' Method Total: 435 (kg CO₂e) |
| Assessor / Organisation: | Mitsubishi Electric | |
| Contact: | embodied.carbon@meuk.mee.com | |



LGH-100RVX-E - Product Information

| | |
|--|------------------|
| Type of product | MVHR |
| Capacity of equipment (kW) | N/A |
| Product weight (kg) | 54 |
| Material breakdown for at least 95% of the product weight? (Y/N) | Y |
| Service life of the product (years) | 15 |
| Type of refrigerant | N/A |
| Refrigerant GWP | N/A |
| Energy consumption of the factory per unit of product (kWh) | 5.15 |
| Location of manufacture | Japan |
| Product Complexity | Category 3: High |



les.mitsubishielectric.co.uk

435 kgCO₂e

54 kg

=

8 kgCO₂e/kg

Embodied Carbon Ventilation

Ventilation **TM65 Calculation**



LGH-100RVX-E

CIBSE TM65 Embodied Carbon Mid-level Calculation



Embodied Carbon Results Breakdown (kg CO₂e)

| | |
|-------------------------|------|
| A1: Material extraction | 237 |
| A2: Transport | 43 |
| A3: Manufacturing | 9 |
| A4: Transport to Site | 13 |
| B1: Use | N/A |
| B3: Repair | 30 |
| C1: Deconstruction | N/A |
| C2: Transport | 1 |
| C3: Waste Processing | 1 |
| C4: Disposal | 0.23 |

Embodied Carbon Results - without Refrigerant Leakage (kg CO₂e)

| | |
|---|-----|
| A1-C4 (excluding B1,C1) | 334 |
| A1-C4 with Buffer Factor (excluding B1, C1) | 435 |

Embodied Carbon Result - Refrigerant Leakage Only (kg CO₂e)

| | |
|--|---|
| B1 (Refrigerant leakage during use) + C1 (Refrigerant leakage end of life) | - |
|--|---|

Assumptions

| | |
|---|-----------------------------------|
| A1: Material carbon coefficient source | TM65 Table 2.1 & The ICE Database |
| B1: Refrigerant annual leakage rate (%) | N/A |
| C1: Refrigerant end of life recovery rate (%) | N/A |
| B3: Materials replaced as part of repair (%) | 10 (TM65 Assumption) |
| C4: Percentage of product going to landfill (%) | 60 (TM65 Assumption) |



Telephone: 01707 282880
email: embodied_carbon@meuk.mee.com
les.mitsubishielectric.co.uk



UNITED KINGDOM Mitsubishi Electric Europe Living Environment Systems Division, Travelers Lane, Hatfield, Hertfordshire, AL10 8BE, England. Telephone: 01707 282880 Fax: 01707 278881
IRELAND Mitsubishi Electric Europe, Westgate Business Park, Ballymount, Dublin 24, Ireland. Telephone: (01) 419 8300 Fax: (01) 419 8590 International code: (003531)

Country of origin: United Kingdom - Japan - Thailand - Malaysia. ©Mitsubishi Electric Europe 2021. Mitsubishi and Mitsubishi Electric are trademarks of Mitsubishi Electric Europe S.p.A. The company reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement. Mitsubishi Electric is constantly developing and improving its products. All descriptions, illustrations, drawings and specifications in this publication present only general particulars and do not form part of any contract. All goods are supplied subject to the Company's General Conditions of Sale, a copy of which is available on request. Third party product and brand names may be trademarks or registered trademarks of their respective owners.

Note: The fuse rating is for guidance only. Please refer to the relevant datasheet for detailed specification. It is the responsibility of a qualified electrician/technical engineer to select the correct cable size and fuse rating based on current regulation and site specific conditions. Mitsubishi Electric air conditioning equipment and heat pump systems contain a flammable greenhouse gas, R410A (GWP=2088), R32 (GWP=675), R450C (GWP=174), R32a (GWP=143), R450A (GWP=130), R450B (GWP=130), R32a (GWP=130) or R132a (GWP=130). These GWP values are based on Regulation (EU) No. 517/2014 from IPCC 4th edition. In case of Regulation (EU) No. 517/2014 from IPCC 3rd edition, these are as follows: R450A (GWP=130), R32 (GWP=675), R450C (GWP=130) or R132a (GWP=130).

Effective as of July 2021



https://library.mitsubishielectric.co.uk/pdf/download_full/4417

Embodied Carbon Outdoor Unit

Heating | TM65 Calculation




PUZ-WM60VAA

CIBSE TM65 Embodied Carbon Mid-level Calculation
Including Operational Carbon Benchmark Estimate



| | | | |
|------------------|-------------------------------|--|------------------------------|
| Assessment date: | 29th of September 2021 | Embodied Carbon Result with 'Mid-level TM65 Calculation' Method: | Operational Carbon Result: |
| Assessor: | Residential Product Marketing | 1,362 (kg CO ₂ e) | 4,078 (kg CO ₂ e) |
| Organisation: | Mitsubishi Electric | Total = 5,440 (kg CO₂e) | |
| Contact: | embodied.carbon@meuk.mee.com | | |



Operational carbon data for heating requirements, according to heat pump ErP fiche at medium temperature (55°C), average climate conditions and equivalent boiler heat output. Gas boiler assumptions: embodied carbon of 300kg CO₂e, efficiency of 93%, service life of 15 years.

Carbon factors sources:

Electrical grid according to Greenbook forecast for residential use. (source: gov.uk, IAG spreadsheet toolkit for valuing changes in greenhouse gas emissions, sheet conversion CO₂). Gas network according to SAP 10.1 carbon emissions factor (source: BRE Group, SAP-10.1-01-10-2019, Page 171).

PUZ-WM60VAA - Product Information

| | |
|--|------------------|
| Type of product | A2W Heat pump |
| Capacity of equipment (kW) | 6 |
| Product weight (kg) | 95.8 |
| Material breakdown for at least 95% of the product weight? (Y/N) | Y |
| Service life of the product (years) | 15 |
| Type of refrigerant | R32 |
| Refrigerant GWP | 675 |
| Refrigerant charge (kg) | 2.2 |
| Energy consumption of the factory per unit of product (kWh) | 66.66 |
| Location of manufacture | UK |
| Product Complexity | Category 3: High |



ecodan.co.uk

1,362 kgCO₂e

96 kg

=

14.2 kgCO₂e/kg

Embodied Carbon Outdoor Unit

Heating TM65 Calculation



PUZ-WM60VAA

CIBSE TM65 Embodied Carbon Mid-level Calculation
Including Operational Carbon Benchmark Estimate

| Embodied Carbon Results Breakdown (kg CO ₂ e) | | | | | | | | | | | | | | | | |
|--|-----------------------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------------------|
| A1: Material extraction | 456 | | | | | | | | | | | | | | | |
| A2: Transport | 76 | | | | | | | | | | | | | | | |
| A3: Manufacturing | 77 | | | | | | | | | | | | | | | |
| A4: Transport to Site | 1 | | | | | | | | | | | | | | | |
| B1: Use | 446 | | | | | | | | | | | | | | | |
| B3: Repair | 63 | | | | | | | | | | | | | | | |
| C1: Deconstruction | 15 | | | | | | | | | | | | | | | |
| C2: Transport | 1 | | | | | | | | | | | | | | | |
| C3: Waste Processing | 19 | | | | | | | | | | | | | | | |
| C4: Disposal | 0 | | | | | | | | | | | | | | | |
| Embodied Carbon Results - without Refrigerant Leakage (kg CO ₂ e) | | | | | | | | | | | | | | | | |
| A1-C4 (excluding B1,C1) | 693 | | | | | | | | | | | | | | | |
| A1-C4 with Buffer Factor (excluding B1, C1) | 901 | | | | | | | | | | | | | | | |
| Embodied Carbon Result - Refrigerant Leakage Only (kg CO ₂ e) | | | | | | | | | | | | | | | | |
| B1 (Refrigerant leakage during use) + C1 (Refrigerant leakage end of life) | 460 | | | | | | | | | | | | | | | |
| Assumptions | | | | | | | | | | | | | | | | |
| A1: Material carbon coefficient source | TM65 Table 2.1 & The ICE Database | | | | | | | | | | | | | | | |
| B1: Refrigerant annual leakage rate (%) | 2 (TM65 Assumption) | | | | | | | | | | | | | | | |
| C1: Refrigerant end of life recovery rate (%) | 99 (TM65 Assumption) | | | | | | | | | | | | | | | |
| B3: Materials replaced as part of repair (%) | 10 (TM65 Assumption) | | | | | | | | | | | | | | | |
| C4: Percentage of product going to landfill (%) | 30 (TM65 Assumption) | | | | | | | | | | | | | | | |
| Operational Carbon | | | | | | | | | | | | | | | | |
| Year ¹ | Y1 | Y2 | Y3 | Y4 | Y5 | Y6 | Y7 | Y8 | Y9 | Y10 | Y11 | Y12 | Y13 | Y14 | Y15 | Cumulative Total |
| Heat Pump (kg CO ₂ e) | 355 | 371 | 346 | 349 | 327 | 349 | 331 | 305 | 275 | 242 | 203 | 188 | 164 | 136 | 136 | 4,078 |

Note: kg CO₂e calculation results are rounded to the nearest whole number. ¹ Y1 = starting from 2022

$$456 + 76 + 77 + 1 = 610$$

$$96 \text{ kg} = 6.35 \text{ kgCO}_2\text{e/kg}$$



Telephone: 01 707 282880
email: heating@meuk.mee.com
ecodan.co.uk



UNITED KINGDOM Mitsubishi Electric Europe Living Environment Systems Division, Travelers Lane, Hatfield, Hertfordshire, AL10 8XB, England. Telephone: 01707 282880 Fax: 01707 278881
IRELAND Mitsubishi Electric Europe, Westgate Business Park, Ballymount, Dublin 24, Ireland. Telephone: (01) 419 8800 Fax: (01) 419 8890 International code: (003531)

Country of origin: United Kingdom - Japan - Thailand - Malaysia. ©Mitsubishi Electric Europe 2021. Mitsubishi and Mitsubishi Electric are trademarks of Mitsubishi Electric Europe B.V. The company reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement. Mitsubishi Electric is constantly developing and improving its products. All descriptions, illustrations, drawings and specifications in this publication present only general particulars and shall not form part of any contract. All goods are supplied subject to the Company's General Conditions of Sale, a copy of which is available on request. Third party products and brand names may be trademarks or registered trademarks of their respective owners.
Note: The fuse rating is for guidance only. Please refer to the relevant database for detailed specification. It is the responsibility of a qualified electrical/electrical engineer to select the correct cable size and fuse rating based on current regulation and site specific conditions. Mitsubishi Electric's air conditioning equipment and/or pump systems contain a fluorinated greenhouse gas, R410A (GWP:2088), R32 (GWP:675), R422C (GWP:1714), R134a (GWP:1430), R613A (GWP:151), H434B (GWP:166), R1234ze (GWP:1 or R1234yf (GWP:4). These GWP values are based on Regulation (EU) No 517/2014 from IPCC 4th edition. In case of Regulation (EU) No 609/2011 from IPCC 3rd edition, these are as follows: R410A (GWP:1876), R32 (GWP:650), R422C (GWP:1660) or R134a (GWP:1300).

Effective as of November 2021



Embodied Carbon Indoor Unit


Air Conditioning TM65 Calculation



PEFY-P15VMS1-E

CIBSE TM65 Embodied Carbon Mid-level Calculation

| | | |
|--------------------------|------------------------------|--|
| Assessment Date: | 14th July 2021 | Embodied Carbon Result with 'Mid-level TM65 Calculation' Method Total: 245 (kg CO₂e) |
| Assessor / Organisation: | Mitsubishi Electric | |
| Contact: | embodied.carbon@meuk.mee.com | |



PEFY-P15VMS1-E - Product Information

| | |
|--|------------------|
| Type of product | VRF Indoor Unit |
| Capacity of equipment (kW) | 1.5 |
| Product weight (kg) | 19 |
| Material breakdown for at least 95% of the product weight? (Y/N) | Y |
| Service life of the product (years) | 15 |
| Type of refrigerant | R410A |
| Refrigerant GWP | 2088 |
| Energy consumption of the factory per unit of product (kWh) | 9.48 |
| Location of manufacture | Asia |
| Product Complexity | Category 3: High |



les.mitsubishielectric.co.uk

$$\frac{245}{19 \text{ kg}} = 12.9 \text{ kgCO}_2\text{e/kg}$$

Embodied Carbon Indoor Unit

Air Conditioning TM65 Calculation



PEFY-P15VMS1-E

CIBSE TM65 Embodied Carbon Mid-level Calculation



Embodied Carbon Results Breakdown (kg CO₂e)

| | |
|-------------------------|-----|
| A1: Material extraction | 117 |
| A2: Transport | 15 |
| A3: Manufacturing | 32 |
| A4: Transport to Site | 5 |
| B1: Use | - |
| B3: Repair | 17 |
| C1: Deconstruction | - |
| C2: Transport | 0.3 |
| C3: Waste Processing | 3 |
| C4: Disposal | 0.1 |

Embodied Carbon Results - without Refrigerant Leakage (kg CO₂e)

| | |
|---|-----|
| A1-C4 (excluding B1,C1) | 189 |
| A1-C4 with Buffer Factor (excluding B1, C1) | 245 |

Embodied Carbon Result - Refrigerant Leakage Only (kg CO₂e)

| | |
|--|---|
| B1 (Refrigerant leakage during use) + C1 (Refrigerant leakage end of life) | - |
|--|---|

Assumptions

| | |
|---|-----------------------------------|
| A1: Material carbon coefficient source | TM65 Table 2.1 & The ICE Database |
| B1: Refrigerant annual leakage rate (%) | 6 (TM65 Assumption) |
| C1: Refrigerant end of life recovery rate (%) | 97 (TM65 Assumption) |
| B3: Materials replaced as part of repair (%) | 10 (TM65 Assumption) |
| C4: Percentage of product going to landfill (%) | 30 (TM65 Assumption) |



Telephone: 01707 262880
email: embodied.carbon@meeuk.com
les.mitsubishielectric.co.uk



@meeuk_les
@green_gateway



Mitsubishi Electric Living
Environmental Systems UK



Mitsubishi Electric
Cooling and Heating UK



mitsubishielectricuk_les



Mitsubishi Electric Living
Environmental Systems UK



YouTube icon

UNITED KINGDOM Mitsubishi Electric Europe Living Environment Systems Division, Travelers Lane, Hatfield, Hertfordshire, AL10 9XB, England. Telephone: 01707 262880 Fax: 01707 278881
IRELAND Mitsubishi Electric Europe, Westgate Business Park, Ballymount, Dublin 24, Ireland. Telephone: (01) 419 8800 Fax: (01) 419 8890 International code: (003531)

Country of origin: United Kingdom - Japan - Thailand - Malaysia. ©Mitsubishi Electric Europe 2021. Mitsubishi and Mitsubishi Electric are trademarks of Mitsubishi Electric Europe E.V. The company reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement. Mitsubishi Electric is constantly developing and improving its products. All descriptions, illustrations, drawings and specifications in this publication represent only general particulars and are not formed part of any contract. All goods are supplied subject to the Company's General Conditions of Sale, a copy of which is available on request. The company product and brand names may be trademarks or registered trademarks of their respective owners.

Note: The fan rating is for guidance only. Please refer to the relevant catalogue for detailed specification. It is the responsibility of a qualified electrical engineer to select the correct cable size and fuse rating based on current regulation and site specific conditions. Mitsubishi Electric's air conditioning equipment and heat pump systems contain a fluorinated greenhouse gas, R410A (GWP-2088), R32 (GWP-675), R437C (GWP-1774), R134a (GWP-1430), R407C (GWP-1975), R454B (GWP-133), R1234ze (GWP-7) or R1234yf (GWP-4). These GWP values are based on Regulation (EU) No 517/2014 from IPCC 4th edition. In case of Regulation (EU) No 626/2011 from IPCC 3rd edition, these are as follows: R410A (GWP-1975), R32 (GWP-675), R437C (GWP-1920) or R134a (GWP-1300).

Effective as of August 2021



greengateway.mitsubishielectric.co.uk